

Quakers Hill Wastewater Treatment Plant

2022-23 Pollution Monitoring Summary



EPL 1724

Summary period: 01-07-2022 to 30-06-2023

Date published: 01-09-2023

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 1: 50 percentile yearly summary

EPA Point 4 Site code QH0004		Point description: Downstream of the overflow weir in the clean water tank							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits	
biochemical oxygen demand	mg/L	every 6 days	61	<2	4	10	<2	yes	
nitrogen (ammonia)	mg/L	every 6 days	61	<0.01	0.6	0.9	0.01	yes	
total suspended solids	mg/L	every 6 days	61	<2	3	5	<2	yes	

Table 1: 50 percentile yearly summary

EPA Point 5 Site code QH0005		Point description: At the outlet of the chlorine contact tank							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits	
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	12	100	100	50	100	yes	

Quakers Hill Wastewater Treatment Plant

2022-23 Pollution Monitoring Summary

EPL 1724

Summary period: 01-07-2022 to 30-06-2023

Date published: 01-09-2023



Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 2: 80 percentile yearly summary

EPA Point 5 Site code QH0005		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	80 percentile limit	80 percentile value	within limits
faecal coliforms	CFU/100mL	every 6 days	60	<1	290	200	40	yes

Quakers Hill Wastewater Treatment Plant

2022-23 Pollution Monitoring Summary

EPL 1724



Summary period: 01-07-2022 to 30-06-2023

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Date published: 01-09-2023

Table 3: 90 percentile yearly summary

EPA Point 4 Site code QH0004		Point description: Downstream of the overflow weir in the clean water tank							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limit	
aluminium	ug/L	monthly	12	89	185	190	178	yes	
biochemical oxygen demand	mg/L	every 6 days	61	<2	4	15	<2	yes	
cadmium	ug/L	monthly	12	<0.1	<0.1	0.3	<0.1	yes	
chromium	ug/L	monthly	12	0.3	1.4	4	1.3	yes	
copper	ug/L	monthly	12	2.3	5.7	6	4.9	yes	
nitrogen (ammonia)	mg/L	every 6 days	61	<0.01	0.6	1.4	0.14	yes	
total suspended solids	mg/L	every 6 days	61	<2	3	10	<2	yes	
zinc	ug/L	monthly	12	12	25	41	24	yes	

Table 3: 90 percentile yearly summary

EPA Point 5 Site code QH0005		Point description: At the outlet of the chlorine contact tank							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limit	
chlorine (total residual)	mg/L	every 6 days	60	<0.04	0.38	0.1	<0.04	yes	
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	60	<30	yes	

Quakers Hill Wastewater Treatment Plant

2022-23 Pollution Monitoring Summary

EPL 1724

Summary period: 01-07-2022 to 30-06-2023

Date published: 01-09-2023



Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 4: 100 percentile yearly summary

EPA Point 4 Site code QH0004		Point description: Downstream of the overflow weir in the clean water tank							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	100 percentile limit	100 percentile value	within limits	
nitrogen (total)	mg/L	every 6 days	61	2.66	8.47	45	8.47	yes	
phosphorus	mg/L	every 6 days	61	0.05	0.29	5	0.29	yes	

Quakers Hill Wastewater Treatment Plant

2022-23 Pollution Monitoring Summary

EPL 1724

Summary period: 01-07-2022 to 30-06-2023

Date published: 01-09-2023



Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 5: Average yearly summary

EPA Point 4 Site code QH0004		Point description: Downstream of the overflow weir in the clean water tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average limit	Average value	within limits
aluminium	ug/L	monthly	12	89	185	120	129	no ¹
cadmium	ug/L	monthly	12	<0.1	<0.1	0.2	<0.1	yes
chromium	ug/L	monthly	12	0.3	1.4	3	1	yes
copper	ug/L	monthly	12	2.3	5.7	5	4	yes
zinc	ug/L	monthly	12	12	25	34	18	yes

Table 5: Average yearly summary

EPA Point 5 Site code QH0005		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average limit	Average value	within limits
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	30	<30	yes

¹ Aluminium average limit exceedance is believed to be related to 60% of facility inflow being diverted to activated granular sludge as part of the Lower South Creek Treatment Upgrade Program.