

Riverstone Wastewater Treatment Plant

2023-24 Pollution Monitoring Summary



EPL 1796

Summary period: 01-07-2023 to 30-06-2024

Date published: 01-09-2024

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 1: 50 percentile yearly summary

EPA Point 3 Site code RS0003		Point description: Downstream of the weir in the chlorine contact tank							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits	
biochemical oxygen demand	mg/L	every 6 days	61	<2	<2	10	<2	yes	
nitrogen (ammonia)	mg/L	every 6 days	61	<0.01	4.95	0.9	0.02	yes	
total suspended solids	mg/L	every 6 days	61	<2	5	5	<2	yes	

Table 1: 50 percentile yearly summary

EPA Point 4 Site code RS0004		Point description: At the outlet of the chlorine contact tank							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits	
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	12	82	100	50	100	yes	

Riverstone Wastewater Treatment Plant

2023-24 Pollution Monitoring Summary

EPL 1796

Summary period: 01-07-2023 to 30-06-2024

Date published: 01-09-2024

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 2: 80 percentile yearly summary

EPA Point 4 Site code RS0004		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	80 percentile limit	80 percentile value	within limits
faecal coliforms	CFU/100mL	every 6 days	61	<1	23	200	5	yes

Riverstone Wastewater Treatment Plant

2023-24 Pollution Monitoring Summary

EPL 1796



Summary period: 01-07-2023 to 30-06-2024

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 3: 90 percentile yearly summary								
EPA Point 3 Site code RS0003	Point description: Downstream of the weir in the chlorine contact tank							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limit
aluminium	ug/L	monthly	12	47	119	240	84	yes
biochemical oxygen demand	mg/L	every 6 days	61	<2	<2	15	<2	yes
copper	ug/L	monthly	12	1.3	2.7	6	2.6	yes
iron	ug/L	monthly	12	12	20	96	17	yes
nitrogen (ammonia)	mg/L	every 6 days	61	<0.01	4.95	1.4	0.06	yes
total suspended solids	mg/L	every 6 days	61	<2	5	10	<2	yes
zinc	ug/L	monthly	12	7	16	56	14	yes

Table 3: 90 percentile yearly summary								
EPA Point 4 Site code RS0004	Point description: At the outlet of the chlorine contact tank							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limit
chlorine (total residual)	mg/L	every 6 days	61	<0.04	0.04	0.1	<0.04	yes
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	60	<30	yes

Riverstone Wastewater Treatment Plant

2023-24 Pollution Monitoring Summary

EPL 1796

Summary period: 01-07-2023 to 30-06-2024

Date published: 01-09-2024



Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 4: 100 percentile yearly summary

EPA Point 3 Site code RS0003		Point description: Downstream of the weir in the chlorine contact tank							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	100 percentile limit	100 percentile value	within limits	
nitrogen (total)	mg/L	every 6 days	61	1.19	8.59	45	8.59	yes	
phosphorus	mg/L	every 6 days	61	0.01	0.09	5	0.09	yes	

Riverstone Wastewater Treatment Plant

2023-24 Pollution Monitoring Summary

EPL 1796

Summary period: 01-07-2023 to 30-06-2024

Date published: 01-09-2024



Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 5: Average yearly summary

EPA Point 3 Site code RS0003		Point description: Downstream of the weir in the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average limit	Average value	within limits
aluminium	ug/L	monthly	12	47	119	133	69	yes
copper	ug/L	monthly	12	1.3	2.7	5	1.9	yes
iron	ug/L	monthly	12	12	20	55	15	yes
zinc	ug/L	monthly	12	7	16	31	11	yes

Table 5: Average yearly summary

EPA Point 4 Site code RS0004		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average limit	Average value	within limits
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	30	<30	yes