

Riverstone Wastewater Treatment Plant

2024-25 Pollution Monitoring Summary



EPL 1796

Summary period: 01-07-2024 to 30-06-2025

Date published: 01-08-2025

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 1: 50 percentile yearly summary								
EPA Point 3 Site code RS0003		Point description: Downstream of the weir in the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
biochemical oxygen demand	mg/L	every 6 days	60	<2	<2	10	<2	yes
nitrogen (ammonia)	mg/L	every 6 days	60	<0.01	1.76	0.9	0.02	yes
total suspended solids	mg/L	every 6 days	60	<2	2	5	<2	yes

Table 1: 50 percentile yearly summary								
EPA Point 4 Site code RS0004		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	12	100	70.7	50	100	yes

Riverstone Wastewater Treatment Plant

2024-25 Pollution Monitoring Summary



EPL 1796

Summary period: 01-07-2024 to 30-06-2025

Date published: 01-08-2025

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 2: 80 percentile yearly summary								
EPA Point 4 Site code RS0004		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	80 percentile limit	80 percentile value	within limits
faecal coliforms	CFU/100mL	every 6 days	61	<1	560	200	5	yes

Riverstone Wastewater Treatment Plant

2024-25 Pollution Monitoring Summary

EPL 1796



Summary period: 01-07-2024 to 30-06-2025

Date published: 01-08-2025

Licensee: Sydney Water Corporation
 PO Box 399
 PARRAMATTA NSW 2124

Table 3: 90 percentile yearly summary								
EPA Point 3 Site code RS0003		Point description: Downstream of the weir in the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limit
aluminium	ug/L	monthly	12	36	150	240	86	yes
biochemical oxygen demand	mg/L	every 6 days	60	<2	<2	15	<2	yes
copper	ug/L	monthly	12	1.1	2.5	6	2.4	yes
iron	ug/L	monthly	12	9	38	96	27	yes
nitrogen (ammonia)	mg/L	every 6 days	60	<0.01	1.76	1.4	0.1	yes
total suspended solids	mg/L	every 6 days	60	<2	2	10	<2	yes
zinc	ug/L	monthly	12	8	16	56	15	yes

Table 3: 90 percentile yearly summary								
EPA Point 4 Site code RS0004		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limit
chlorine (total residual)	mg/L	every 6 days	61	<0.04	0.13	0.1	<0.04	yes
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	60	<30	yes

Riverstone Wastewater Treatment Plant

2024-25 Pollution Monitoring Summary

EPL 1796



Summary period: 01-07-2024 to 30-06-2025

Date published: 01-08-2025

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 4: 100 percentile yearly summary								
EPA Point 3 Site code RS0003		Point description: Downstream of the weir in the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	100 percentile limit	100 percentile value	within limits
nitrogen (total)	mg/L	every 6 days	60	2.07	8.41	45	8.41	yes
phosphorus	mg/L	every 6 days	60	0.01	0.53	5	0.53	yes

Riverstone Wastewater Treatment Plant
2024-25 Pollution Monitoring Summary
EPL 1796



Summary period: 01-07-2024 to 30-06-2025
Date published: 01-08-2025

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 5: Average yearly summary								
EPA Point 3 Site code RS0003		Point description: Downstream of the weir in the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average limit	Average value	within limits
aluminium	ug/L	monthly	12	36	150	133	69	yes
copper	ug/L	monthly	12	1.1	2.5	5	2	yes
iron	ug/L	monthly	12	9	38	55	18	yes
zinc	ug/L	monthly	12	8	16	31	11	yes

Table 5: Average yearly summary								
EPA Point 4 Site code RS0004		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average limit	Average value	within limits
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	30	<30	yes