

Riverstone Wastewater Treatment Plant

2025-26 Pollution Monitoring Summary



EPL 1796

Summary period: 01-07-2025 to 30-06-2026

Date published: 20-07-2026

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 50 percentile yearly summary								
EPA Point 3 Site code RS0003		Point description: Downstream of the weir in the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
biochemical oxygen demand	mg/L	every 6 days	61	<2	<2	10	<2	yes
nitrogen (ammonia)	mg/L	every 6 days	61	0.01	5.06	0.9	0.07	yes
total suspended solids	mg/L	every 6 days	61	<2	3	5	<2	yes
nitrogen (total)	mg/L	every 6 days	61	1.52	9.69	6	3.15	yes
phosphorus (total)	mg/L	every 6 days	61	<0.010	0.071	0.1	0.016	yes

Table 1: 50 percentile yearly summary								
EPA Point 4 Site code RS0004		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	12	100	100	50	100	yes

Riverstone Wastewater Treatment Plant

2025-26 Pollution Monitoring Summary



EPL 1796

Summary period: 01-07-2025 to 30-06-2026

Date published: 20-07-2026

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 2: 80 percentile yearly summary								
EPA Point 4 Site code RS0004		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	80 percentile limit	80 percentile value	within limits
faecal coliforms	CFU/100mL	every 6 days	61	<1	64	200	4	yes

Riverstone Wastewater Treatment Plant

2025-26 Pollution Monitoring Summary

EPL 1796



Summary period: 01-07-2025 to 30-06-2026

Date published: 20-07-2026

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 3: 90 percentile yearly summary								
EPA Point 3 Site code RS0003		Point description: Downstream of the weir in the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limit
aluminium	ug/L	monthly	12	49	187	240	109	yes
biochemical oxygen demand	mg/L	every 6 days	61	<2	<2	15	<2	yes
copper	ug/L	monthly	12	0.5	2	6	1.8	yes
iron	ug/L	monthly	12	16	61	96	39	yes
nitrogen (ammonia)	mg/L	every 6 days	61	0.01	5.06	1.4	0.49	yes
total suspended solids	mg/L	every 6 days	61	<2	3	10	<2	yes
zinc	ug/L	monthly	12	15	27	56	24	yes

Table 3: 90 percentile yearly summary								
EPA Point 4 Site code RS0004		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limit
chlorine (total residual)	mg/L	every 6 days	61	<0.04	<0.04	0.1	<0.04	yes
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	60	<30	yes

Riverstone Wastewater Treatment Plant

2025-26 Pollution Monitoring Summary

EPL 1796



Summary period: 01-07-2025 to 30-06-2026

Date published: 20-07-2026

Licensee: Sydney Water Corporation
 PO Box 399
 PARRAMATTA NSW 2124

Table 5: Average yearly summary								
EPA Point 3 Site code RS0003		Point description: Downstream of the weir in the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average limit	Average value	within limits
aluminium	ug/L	monthly	12	49	187	133	81	yes
copper	ug/L	monthly	12	0.5	2	5	1.2	yes
iron	ug/L	monthly	12	16	61	55	27	yes
zinc	ug/L	monthly	12	15	27	31	19	yes

Table 5: Average yearly summary								
EPA Point 4 Site code RS0004		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average limit	Average value	within limits
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	30	<30	yes