

St Marys Advance Water Treatment Plant

2019-2020 Pollution Monitoring Summary



EPL 13210

Summary period: 01-07-2019 to 30-06-2020

Date published: 10-08-2020

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 1: 50 percentile yearly summary

EPA Point 2 Site code SMHTRW		Point description: Highly treated recycled water balance tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
Ammonia NH3-N	mg/L	every 6 days	29	0.01	0.17	2	0.07	yes
nitrogen (total)	mg/L	every 6 days	29	0.14	0.31	10	0.23	yes
phosphorus (total)	mg/L	every 6 days	29	<0.002	0.005	0.2	<0.002	yes

Table 2: 90 percentile yearly summary

EPA Point 2 Site code SMHTRW		Point description: Highly treated recycled water balance tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
Ammonia NH3-N	mg/L	every 6 days	29	0.01	0.17	5	0.15	yes
nitrogen (total)	mg/L	every 6 days	29	0.14	0.31	15	0.28	yes
phosphorus (total)	mg/L	every 6 days	29	<0.002	0.005	0.4	0.002	yes

Table 2: 100 percentile yearly summary

EPA Point 2 Site code SMHTRW		Point description: Highly treated recycled water balance tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	100 percentile limit	100 percentile value	within limits
Ammonia NH3-N	mg/L	every 6 days	29	0.01	0.17	0.9	0.17	yes

St Marys Advance Water Treatment Plant

2019-2020 Pollution Monitoring Summary



EPL 13210

Summary period: 01-07-2019 to 30-06-2020

Date published: 10-08-2020

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 3: 90 percentile yearly summary

EPA Point 1 Site code PRHTRW		Point description: The discharge channel from Penrith STP							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits	
chlorine (total residual)	mg/L	every 6 days	41	<0.04	0.7	0.1	0.08	yes	