

St Marys Advanced Water Treatment Plant

2025-2026 Pollution Monitoring Summary



EPL 13210

Summary period: 01-07-2025 to 30-06-2026

Date published: 15-07-2026

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 50 percentile yearly summary

EPA Point 2 Site code SMHTRW		Point description: Highly treated recycled water balance tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
Ammonia NH3-N	mg/L	every 6 days	0	-	-	0.3	-	-
nitrogen (total)	mg/L	every 6 days	0	-	-	0.8	-	-
phosphorus (total)	mg/L	every 6 days	0	-	-	0.03	-	-

Table 2: 90 percentile yearly summary

EPA Point 2 Site code SMHTRW		Point description: Highly treated recycled water balance tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
Ammonia NH3-N	mg/L	every 6 days	0	-	-	0.75	-	-
nitrogen (total)	mg/L	every 6 days	0	-	-	1.5	-	-
phosphorus (total)	mg/L	every 6 days	0	-	-	0.1	-	-

Table 3: 100 percentile yearly summary

EPA Point 2 Site code SMHTRW		Point description: Highly treated recycled water balance tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	100 percentile limit	100 percentile value	within limits
Ammonia NH3-N	mg/L	every 6 days	0	-	-	0.9	-	-

Flow from St Marys AWTP to St Marys WRRF has been offline during the 2025-26 financial year.

Table 4: 90 percentile yearly summary

EPA Point 1 Site code PRHTRW		Point description: The discharge channel from Penrith STP						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
chlorine (total residual)	mg/L	every 6 days	0	-	-	0.1	-	-

Flow from St Marys AWTP to Penrith WRRF has been offline during the 2025-26 financial year.