

St Marys Wastewater Treatment Plant

2018-19 Pollution Monitoring Summary



EPL 1729

Summary period: 01-07-2018 to 30-06-2019

Date published: 09-09-2019

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 50 percentile yearly summary

EPA Point 5 Site code SM0005		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
carbonaceous biochemical oxygen demand	mg/L	every 6 days	61	<2	<2	10	<2	yes
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	12	100	100	50	100	yes
nitrogen (ammonia)	mg/L	every 6 days	61	0.01	1.87	1	0.03	yes
total suspended solids	mg/L	every 6 days	61	<2	3	10	<2	yes

St Marys Wastewater Treatment Plant

2018-19 Pollution Monitoring Summary



EPL 1729

Summary period: 01-07-2018 to 30-06-2019

Date published: 09-09-2019

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 2: 80 percentile yearly summary

EPA Point 5 Site code SM0005		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	80 percentile limit	80 percentile value	within limits
faecal coliforms	CFU/100mL	every 6 days	61	<1	48	200	3	yes

St Marys Wastewater Treatment Plant

2018-19 Pollution Monitoring Summary

EPL 1729



Summary period: 01-07-2018 to 30-06-2019

Date published: 09-09-2019

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 3: 90 percentile yearly summary

EPA Point 5 Site code SM0005		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limit
aluminium	ug/L	monthly	12	57	147	1,100	140	yes
carbonaceous biochemical oxygen demand	mg/L	every 6 days	61	<2	<2	15	<2	yes
chlorine (total residual)	mg/L	every 6 days	61	<0.04	0.04	0.1	<0.04	yes
copper	ug/L	monthly	12	1.5	3.4	90	3.4	yes
diazinon	ug/L	monthly	12	<0.1	<0.1	3.7	<0.1	yes
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	180	<30	yes
iron	ug/L	monthly	12	26	58	800	52	yes
nickel	ug/L	monthly	12	2.1	3.8	16.9	3.6	yes
nitrogen (ammonia)	mg/L	every 6 days	61	0.01	1.87	5	0.78	yes
total suspended solids	mg/L	every 6 days	61	<2	3	15	<2	yes
zinc	ug/L	monthly	12	13	27	100	23	yes

St Marys Wastewater Treatment Plant

2018-19 Pollution Monitoring Summary

EPL 1729

Summary period: 01-07-2018 to 30-06-2019

Date published: 09-09-2019



Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 4: 100 percentile yearly summary

EPA Point 5 Site code SM0005		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	100 percentile limit	100 percentile value	within limits
nitrogen (total)	mg/L	every 6 days	61	2.34	7.61	45	7.61	yes
phosphorus	mg/L	every 6 days	61	0.02	0.04	5	0.04	yes

St Marys Wastewater Treatment Plant

2018-19 Pollution Monitoring Summary

EPL 1729



Summary period: 01-07-2018 to 30-06-2019

Date published: 09-09-2019

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 5: Average yearly summary

EPA Point 5 Site code SM0005		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average limit	Average value	within limits
aluminium	ug/L	monthly	12	57	147	120	100	yes
copper	ug/L	monthly	12	1.5	3.4	17.6	3	yes
diazinon	ug/L	monthly	12	<0.1	<0.1	0.6	<0.1	yes
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	66	<30	yes
iron	ug/L	monthly	12	26	58	430	40	yes
nickel	ug/L	monthly	12	2.1	3.8	12.3	3	yes
zinc	ug/L	monthly	12	13	27	40	20	yes