

Wallacia Wastewater Treatment Plant

2024-25 Pollution monitoring yearly limit summaries



EPL 12235

Summary period: 01-07-2024 to 30-06-2025

Date published: 01-08-2025

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

50 percentile yearly summary								
EPA Point 4 Site code WL0004		Point description: From the dechlorination tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
biochemical oxygen demand	mg/L	every 6 days	61	<2	2	5	<2	yes
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	12	100	100	50	100	yes
nitrogen (ammonia)	mg/L	every 6 days	61	0.01	4.87	0.5	0.14	yes
nitrogen (total)	mg/L	every 6 days	61	3.32	8.98	7.5	6.18	yes
phosphorus (total)	mg/L	every 6 days	61	0.02	0.31	0.15	0.04	yes
total suspended solids	mg/L	every 6 days	61	<2	3	5	<2	yes

80 percentile yearly summary								
EPA Point 4 Site code WL0004		Point description: From the dechlorination tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	80 percentile limit	80 percentile value	within limits
faecal coliforms	CFU/100mL	every 6 days	61	<1	1,400	200	35	yes

Wallacia Wastewater Treatment Plant

2024-25 Pollution monitoring yearly limit summaries



EPL 12235

Summary period: 01-07-2024 to 30-06-2025
Date published: 01-08-2025

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

90 percentile yearly summary								
EPA Point 4 Site code WL0004		Point description: From the dechlorination tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
aluminium	ug/L	monthly	12	<5	20	85	10	yes
biochemical oxygen demand	mg/L	every 6 days	61	<2	2	10	<2	yes
copper	ug/L	monthly	12	2.8	14.9	31	11.7	yes
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	60	<30	yes
nitrogen (ammonia)	mg/L	every 6 days	61	0.01	4.87	1	0.48	yes
nitrogen (total)	mg/L	every 6 days	61	3.32	8.98	10	8.12	yes
nonylphenol ethoxylate	ug/L	monthly	12	<5	<5	580	<5	yes
phosphorus (total)	mg/L	every 6 days	61	0.02	0.31	0.3	0.09	yes
total suspended solids	mg/L	every 6 days	61	<2	3	10	<2	yes
zinc	ug/L	monthly	12	11	46	26	21	yes

Wallacia Wastewater Treatment Plant

2024-25 Pollution monitoring yearly limit summaries



EPL 12235

Summary period: 01-07-2024 to 30-06-2025

Date published: 01-08-2025

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Average yearly summary								
EPA Point 4 Site code WL0004		Point description: From the dechlorination tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average Limit	Average value	within limits
aluminium	ug/L	monthly	12	<5	20	81	6	yes
copper	ug/L	monthly	12	2.8	14.9	18	6	yes
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	30	<30	yes
nonylphenol ethoxylate	ug/L	monthly	12	<5	<5	64	<5	yes
zinc	ug/L	monthly	12	11	46	20	19	yes