Warriewood Wastewater Treatment Plant 2024-25 Pollution monitoring yearly limit summaries



EPL 1784

Summary period: 01-07-2024 to 30-06-2025

Date published: 01-08-2025

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

50 percentile yearly summary								
EPA Point 5 Site code WW0005	Point description: Outfall pipeline on the plant's eastern boundary							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
faecal coliforms	CFU/100mL	every 6 days	61	2	520,000	200	41	yes
total suspended solids	mg/L	every 6 days	61	3	88	30	7	yes

80 percentile yearly summary								
EPA Point 5 Site code WW0005 Point description: Outfall pipeline on the plant's eastern boundary								
pollutant	unit of	sampling frequency	number of samples	minimum result	maximum result	80 percentile limit	80 percentile value	within limits
•	measure		Samples	resuit		1111111	value	เเเเเธ
total suspended solids	mg/L	every 6 days	61	3	88	40	12	yes

90 percentile yearly summary										
EPA Point 5 Site code WW0005 pollutant	Point description: Outfall pipeline on the plant's eastern boundary									
	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits		
aluminium	ug/L	monthly	12	6	47	150	30	yes		
copper	ug/L	monthly	12	3.3	8.5	30	7.5	yes		
cyanide	ug/L	monthly	12	<5	17	30	16	yes		
nonylphenol ethoxylate	ug/L	monthly	12	<5	8	22	7	yes		

Warriewood Wastewater Treatment Plant 2024-25 Pollution monitoring yearly limit summaries



EPL 1784

Summary period: 01-07-2024 to 30-06-2025

Date published: 01-08-2025

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

90 percentile yearly summary								
EPA Point 5 Site code WW0005 Point description: Outfall pipeline on the plant's eastern boundary								
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	12	100	39.6	4	39.6	yes

Average yearly summary										
EPA Point 5 Site code WW0005	Point description: Outfall pipeline on the plant's eastern boundary									
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average Limit	Average value	within limits		
aluminium	ug/L	monthly	12	6	47	80	18	yes		
copper	ug/L	monthly	12	3.3	8.5	15	6	yes		
cyanide	ug/L	monthly	12	<5	17	17	10	yes		
nonylphenol ethoxylate	ug/L	monthly	12	<5	8	11	<5	yes		
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	12	39.6	100	6.7	61.8	yes		

Page 2 Of 2