

Winmalee Wastewater Treatment Plant

2022-23 Pollution monitoring yearly limit summaries



EPL 1963

Summary period: 01-07-2022 to 30-06-2023

Date published: 1-09-2023

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

50 percentile yearly summary

EPA Point 4 Site code WM0004		Point description: Downstream of the chamber prior to discharge						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
biochemical oxygen demand	mg/L	every 6 days	61	<2	7	10	<2	yes
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	12	100	100	50	100	yes
nitrogen (ammonia)	mg/L	every 6 days	61	<0.01	6.13	2	0.08	yes
nitrogen (total)	mg/L	every 6 days	61	3.48	15	15	10.5	yes
phosphorus (total)	mg/L	every 6 days	61	0.09	1.68	2	0.26	yes
total suspended solids	mg/L	every 6 days	61	<2	4	10	<2	yes

80 percentile yearly summary

EPA Point 4 Site code WM0004		Point description: Downstream of the chamber prior to discharge						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	80 percentile limit	80 percentile value	within limits
faecal coliforms	CFU/100mL	every 6 days	61	<1	760	200	3	yes

Winmalee Wastewater Treatment Plant

2022-23 Pollution monitoring yearly limit summaries



EPL 1963

Summary period: 01-07-2022 to 30-06-2023

Date published: 1-09-2023

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

90 percentile yearly summary								
EPA Point 4 Site code WM0004		Point description: Downstream of the chamber prior to discharge						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
aluminium	ug/L	monthly	12	<5	51	270	38	yes
biochemical oxygen demand	mg/L	every 6 days	61	<2	7	15	<2	yes
chlorine (total residual)	mg/L	every 6 days	61	<0.04	0.09	0.1	<0.04	yes
copper	ug/L	monthly	12	2.8	6.6	9	5.8	yes
diazinon	ug/L	monthly	12	<0.1	<0.1	0.1	<0.1	yes
iron	ug/L	monthly	12	52	136	880	90	yes
nitrogen (ammonia)	mg/L	every 6 days	61	<0.01	6.13	5	1.63	yes
nitrogen (total)	mg/L	every 6 days	61	3.48	15	20	13.3	yes
phosphorus (total)	mg/L	every 6 days	61	0.09	1.68	3	1.22	yes
total suspended solids	mg/L	every 6 days	61	<2	4	15	<2	yes
zinc	ug/L	monthly	12	12	21	33	20	yes

Winmalee Wastewater Treatment Plant

2022-23 Pollution monitoring yearly limit summaries



EPL 1963

Summary period: 01-07-2022 to 30-06-2023

Date published: 1-09-2023

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Average yearly summary								
EPA Point 4 Site code WM0004		Point description: Downstream of the chamber prior to discharge						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average Limit	Average value	within limits
aluminium	ug/L	monthly	12	<5	51	190	15	yes
copper	ug/L	monthly	12	2.8	6.6	7	4	yes
diazinon	ug/L	monthly	12	<0.1	<0.1	0.2	<0.1	yes
iron	ug/L	monthly	12	52	136	650	74	yes
zinc	ug/L	monthly	12	12	21	25	16	yes