

# North Richmond Water Filtration Plant

## 2018-2019 Pollution Monitoring Summary

### EPL 5425



Summary period: 01-07-2018 to 30-06-2019

Date published: 09-09-2019

**Licensee:** Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 100 percentile yearly summary**

EPA Point 4 Site code EFFQNR1		Point description: Access chamber							
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results	100 percentile limit	100 percentile value	within limits
pH	pH Units	every 25 days	15	7.25	7.6	7.84	6.5 - 8.5	7.84	yes
total suspended solids	mg/L	every 25 days	15	<2	2	12	30	12	yes

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather. 2 Details of any within limit exceptions were provided in monthly reports

**Table 2: Average yearly summary**

EPA Point 4 Site code EFFQNR1		Point description: Access chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
aluminium	mg/L	every 25 days	15	<0.01	0.01	0.03
chlorine (total residual)	mg/L	every 25 days	15	<0.04	0.09	0.29
iron	mg/L	every 25 days	15	0.07	0.37	0.88
manganese	mg/L	every 25 days	15	0.01	0.03	0.06
pH	pH Units	every 25 days	15	7.25	7.6	7.84
total dissolved solids	mg/L	every 25 days	15	94	157	181
total suspended solids	mg/L	every 25 days	15	<2	2	12