

North Richmond Water Filtration Plant

2025-2026 Pollution Monitoring Summary

EPL 5425



Summary period: 01-07-2025 to 30-06-2026
 Date published: 15-07-2026

Licensee: Sydney Water Corporation
 PO Box 399
 PARRAMATTA NSW 2124

Table 1: 100 percentile yearly summary									
EPA Point 4 Site code EFFQNR1		Point description: Access chamber							
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results	100 percentile limit	100 percentile value	within limits
pH	pH Units	min 25 days	12	7.01	7.41	7.56	6.5 - 8.5	7.56	yes
total suspended solids	mg/L	min 25 days	12	<2	5	14	30	14	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Average yearly summary						
EPA Point 4 Site code EFFQNR1		Point description: Access chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
aluminium	mg/L	min 25 days	12	<0.005	0.02	0.07
chlorine (total residual)	mg/L	min 25 days	12	<0.04	0.07	0.14
iron	mg/L	min 25 days	12	0.11	0.79	2.07
manganese	mg/L	min 25 days	12	0.02	0.07	0.15
pH	pH Units	min 25 days	12	7.01	7.41	7.56
total dissolved solids	mg/L	min 25 days	12	102	140	167
total suspended solids	mg/L	min 25 days	12	<2	5	14