

Fairfield Wastewater Treatment Plant 2015-2016 Pollution Monitoring Summary



EPL 372

Summary period: 01-07-2015 to 30-06-2016

Date published: 29-09-2016

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile yearly summary

EPA Point 24 Site code FF0024 Overflow Point		Point description: Effluent channel							
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results	100 percentile limit	100 percentile value	within limits
carbonaceous biochemical oxygen demand	mg/L	on bypass	19	5	29	69	100	69	yes
total suspended solids	mg/L	on bypass	19	12	27	45	120	45	yes

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather. Details of any within limit exceptions were provided in monthly reports