

# Richmond Wastewater Treatment Plant

## 2015-16 Pollution monitoring yearly limit summaries



### EPL 1726

Summary period: 01-07-2015 to 30-06-2016

Date published: 29-09-2016

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

50 percentile yearly summary								
EPA Point 16 Site code RM0016		Point description: Outlet of dechlorination tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
carbonaceous biochemical oxygen demand	mg/L	every 6 days	38	<2	5	10	<2	yes
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly during discharge	6	>100	100	50	100	yes
chlorine (total residual)	mg/L	every 6 days	38	<0.04	0.87	0.1	<0.04	yes
nitrogen (ammonia)	mg/L	every 6 days	38	<0.01	3.8	1	<0.1	yes
nitrogen (total)	mg/L	every 6 days	38	5.36	9.95	10	6.9	yes
phosphorus (total)	mg/L	every 6 days	38	0.01	0.1	0.3	0.03	yes
total suspended solids	mg/L	every 6 days	38	<2	3	10	<2	yes

80 percentile yearly summary								
EPA Point 16 Site code RM0016		Point description: Outlet of dechlorination tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	80 percentile limit	80 percentile value	within limits
faecal coliforms	CFU/100mL	every 6 days	38	<1	720	200	210	no <sup>1</sup>

1. The 80th percentile concentration limit was exceeded during the 2015-16 period. The wastewater treatment plant was performing as expected during this period.

# Richmond Wastewater Treatment Plant

## 2015-16 Pollution monitoring yearly limit summaries



### EPL 1726

Summary period: 01-07-2015 to 30-06-2016

Date published: 29-09-2016

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

90 percentile yearly summary								
EPA Point 16 Site code RM0016		Point description: Outlet of dechlorination tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
carbonaceous biochemical oxygen demand	mg/L	every 6 days	38	<2	5	15	<2	yes
nitrogen (ammonia)	mg/L	every 6 days	38	<0.01	3.8	5	0.3	yes
nitrogen (total)	mg/L	every 6 days	38	5.36	9.95	15	8.42	yes
phosphorus (total)	mg/L	every 6 days	38	0.01	0.1	1	0.05	yes
total suspended solids	mg/L	every 6 days	38	<2	3	15	2	yes

50 percentile yearly summary								
EPA Point 17 Site code RM0017		Point description: Inlet to recycled water pump station						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
carbonaceous biochemical oxygen demand	mg/L	every 6 days	61	<2	12	10	<2	yes
chlorine (total residual)	mg/L	every 6 days	61	0.89	3.8	5	1.38	yes
faecal coliforms	CFU/100mL	every 6 days	61	<1	1	10	<1	yes
nitrogen (ammonia)	mg/L	every 6 days	61	<0.01	0.9	1	0.01	yes
nitrogen (total)	mg/L	every 6 days	61	5.08	10.1	10	7.03	yes
phosphorus (total)	mg/L	every 6 days	61	0.01	0.06	0.3	0.03	yes
total suspended solids	mg/L	every 6 days	61	<2	4	10	<2	yes

# Richmond Wastewater Treatment Plant

## 2015-16 Pollution monitoring yearly limit summaries



### EPL 1726

Summary period: 01-07-2015 to 30-06-2016

Date published: 29-09-2016

**Licensee:** Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

90 percentile yearly summary								
EPA Point 17 Site code RM0017		Point description: Inlet to recycled water pump station						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
carbonaceous biochemical oxygen demand	mg/L	every 6 days	61	<2	12	15	<2	yes
nitrogen (ammonia)	mg/L	every 6 days	61	<0.01	0.9	5	0.24	yes
nitrogen (total)	mg/L	every 6 days	61	5.08	10.1	15	7.98	yes
phosphorus (total)	mg/L	every 6 days	61	0.01	0.06	1	0.04	yes
total suspended solids	mg/L	every 6 days	61	<2	4	15	<2	yes