

# Wallacia Wastewater Treatment Plant

## 2018-19 Pollution monitoring yearly limit summaries



### EPL 12235

Summary period: 01-07-2018 to 30-06-2019

Date published: 07-09-2019

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

50 percentile yearly summary								
EPA Point 4 Site code WL0004		Point description: From the dechlorination tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
carbonaceous biochemical oxygen demand	mg/L	every 6 days	60	<2	3	5	<2	yes
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	12	100	100	50	100	yes
nitrogen (ammonia)	mg/L	every 6 days	60	0.01	1.78	0.5	0.01	yes
nitrogen (total)	mg/L	every 6 days	60	1.99	10.8	7.5	3.69	yes
phosphorus (total)	mg/L	every 6 days	60	0.01	0.08	0.15	0.02	yes
total suspended solids	mg/L	every 6 days	60	<2	3	5	<2	yes

80 percentile yearly summary								
EPA Point 4 Site code WL0004		Point description: From the dechlorination tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	80 percentile limit	80 percentile value	within limits
faecal coliforms	CFU/100mL	every 6 days	61	<1	230	200	7	yes

# Wallacia Wastewater Treatment Plant

## 2018-19 Pollution monitoring yearly limit summaries



### EPL 12235

Summary period: 01-07-2018 to 30-06-2019

Date published: 09-09-2019

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

90 percentile yearly summary								
EPA Point 4 Site code WL0004	Point description: From the dechlorination tank							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
aluminium	ug/L	monthly	12	<5	5	1,500	<5	yes
carbonaceous biochemical oxygen demand	mg/L	every 6 days	60	<2	3	10	<2	yes
copper	ug/L	monthly	12	1.7	9.2	100	4	yes
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	3,300	<30	yes
nitrogen (ammonia)	mg/L	every 6 days	60	0.01	1.78	1	0.11	yes
nitrogen (total)	mg/L	every 6 days	60	1.99	10.8	10	4.88	yes
nonylphenol ethoxylate	ug/L	monthly	12	<5	7	580	<5	yes
phosphorus (total)	mg/L	every 6 days	60	0.01	0.08	0.3	0.02	yes
total suspended solids	mg/L	every 6 days	60	<2	3	10	<2	yes
zinc	ug/L	monthly	12	9	32	110	24	yes

# Wallacia Wastewater Treatment Plant

## 2018-19 Pollution monitoring yearly limit summaries



### EPL 12235

Summary period: 01-07-2018 to 30-06-2019

Date published: 09-09-2019

**Licensee:** Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Average yearly summary								
EPA Point 4 Site code WL0004		Point description: From the dechlorination tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average Limit	Average value	within limits
aluminium	ug/L	monthly	12	<5	5	800	<5	yes
copper	ug/L	monthly	12	1.7	9.2	35	3	yes
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	290	<30	yes
nonylphenol ethoxylate	ug/L	monthly	12	<5	7	64	<5	yes
zinc	ug/L	monthly	12	9	32	87	15	yes