

# West Hornsby Wastewater Treatment Plant

## 2018-19 Pollution monitoring yearly limit summaries



### EPL 1695

Summary period: 01-07-2018 to 30-06-2019

Date published: 09-09-2019

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

50 percentile yearly summary								
EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
carbonaceous biochemical oxygen demand	mg/L	every 6 days	61	<2	9	10	<2	yes
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	12	100	100	50	100	yes
nitrogen (ammonia)	mg/L	every 6 days	61	0.01	8.51	1	0.03	yes
nitrogen (total)	mg/L	every 6 days	61	1.31	12.3	10	4.36	yes
phosphorus (total)	mg/L	every 6 days	61	0.04	0.72	0.3	0.09	yes
total suspended solids	mg/L	every 6 days	61	<2	85	10	2	yes

80 percentile yearly summary								
EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	80 percentile limit	80 percentile value	within limits
faecal coliforms	CFU/100mL	every 6 days	61	8	710,000	200	97	yes

# West Hornsby Wastewater Treatment Plant

## 2018-19 Pollution monitoring yearly limit summaries



### EPL 1695

Summary period: 01-07-2018 to 30-06-2019

Date published: 09-09-2019

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

90 percentile yearly summary								
EPA Point 5 Site code WH0005	Point description: Downstream of the disinfection facilities							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
aluminium	ug/L	monthly	12	151	564	2,300	376	yes
carbonaceous biochemical oxygen demand	mg/L	every 6 days	61	<2	9	15	3	yes
copper	ug/L	monthly	12	2.2	12.7	82	8	yes
cyanide	ug/L	monthly	12	<5	<5	220	<5	yes
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	310	<30	yes
iron	ug/L	monthly	12	34	542	17,100	389	yes
nitrogen (ammonia)	mg/L	every 6 days	61	0.01	8.51	5	1.21	yes
nitrogen (total)	mg/L	every 6 days	61	1.31	12.3	15	7.08	yes
phosphorus (total)	mg/L	every 6 days	61	0.04	0.72	1	0.4	yes
total suspended solids	mg/L	every 6 days	61	<2	85	15	8	yes
zinc	ug/L	monthly	12	11	25	100	20	yes

# West Hornsby Wastewater Treatment Plant

## 2018-19 Pollution monitoring yearly limit summaries



### EPL 1695

Summary period: 01-07-2018 to 30-06-2019

Date published: 09-09-2019

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Average yearly summary								
EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average Limit	Average value	within limits
aluminium	ug/L	monthly	12	151	564	380	285	yes
copper	ug/L	monthly	12	2.2	12.7	17.3	5	yes
cyanide	ug/L	monthly	12	<5	<5	16.5	<5	yes
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	78	<30	yes
iron	ug/L	monthly	12	34	542	620	152	yes
zinc	ug/L	monthly	12	11	25	40	17	yes