

# Cronulla Wastewater Treatment Plant

## June Pollution Monitoring Summary



### EPL 1728

Summary period: 01-06-2018 to 30-06-2018

Date obtained: 04-07-2018

Date published: 11-07-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	40	3	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	30	4	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	106
carbonaceous biochemical oxygen demand	mg/L	every 6 days	4	<2	<2	7
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	7.8
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	8.2
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	4	<5	<5	<5
total suspended solids	mg/L	every 6 days	4	<2	4	13
zinc	ug/L	monthly	1	-	-	23

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	1	56	230
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	239
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

# Cronulla Wastewater Treatment Plant

## May Pollution Monitoring Summary



### EPL 1728

Summary period: 01-05-2018 to 31-05-2018

Date obtained: 06-06-2018

Date published: 13-06-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	40	<2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	30	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	38
carbonaceous biochemical oxygen demand	mg/L	every 6 days	6	<2	<2	<2
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	11.3
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	5.6
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	6	<5	<5	<5
total suspended solids	mg/L	every 6 days	6	<2	<2	<2
zinc	ug/L	monthly	1	-	-	35

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	6	642	2,900
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

# Cronulla Wastewater Treatment Plant

## April Pollution Monitoring Summary



### EPL 1728

Summary period: 01-04-2018 to 30-04-2018

Date obtained: 04-05-2018

Date published: 11-05-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	40	2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	30	2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	29
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	2
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	5.2
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	3.8
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	2
zinc	ug/L	monthly	1	-	-	27

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	1	46	100
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

# Cronulla Wastewater Treatment Plant

## March Pollution Monitoring Summary



### EPL 1728

Summary period: 01-03-2018 to 31-03-2018

Date obtained: 06-04-2018

Date published: 13-04-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	40	<2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	30	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	29
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	5.5
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	5
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	2
zinc	ug/L	monthly	1	-	-	33

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	1	24	46
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

# Cronulla Wastewater Treatment Plant

## February Pollution Monitoring Summary



### EPL 1728

Summary period: 01-02-2018 to 28-02-2018

Date obtained: 07-03-2018

Date published: 15-03-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	40	<2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	30	2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	23
carbonaceous biochemical oxygen demand	mg/L	every 6 days	4	<2	<2	<2
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	5.2
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	12.9
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	4	<5	<5	<5
total suspended solids	mg/L	every 6 days	4	<2	<2	3
zinc	ug/L	monthly	1	-	-	24

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	25	131	310
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

# Cronulla Wastewater Treatment Plant

## January Pollution Monitoring Summary



### EPL 1728

Summary period: 01-01-2018 to 31-01-2018

Date obtained: 19-02-2018

Date published: 23-02-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	40	<2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	30	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	27
carbonaceous biochemical oxygen demand	mg/L	every 6 days	6	<2	<2	<2
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	3.2
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	4.2
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	6	<5	<5	<5
total suspended solids	mg/L	every 6 days	6	<2	<2	<2
zinc	ug/L	monthly	1	-	-	25

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	1	6	16
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

# Cronulla Wastewater Treatment Plant

## December Pollution Monitoring Summary



### EPL 1728

Summary period: 01-12-2017 to 31-12-2017

Date obtained: 23-01-2018

Date published: 29-01-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	40	<2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	30	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	30
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	6.3
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	5.1
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	3
zinc	ug/L	monthly	1	-	-	34

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	1	8	17
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

# Cronulla Wastewater Treatment Plant

## November Pollution Monitoring Summary



### EPL 1728

Summary period: 01-11-2017 to 30-11-2017

Date obtained: 08-12-2017

Date published: 14-12-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	40	<2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	30	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	34
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	2
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	4.7
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	16.4
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	30

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	<1	5	20
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2



# Cronulla Wastewater Treatment Plant

## October Pollution Monitoring Summary



### EPL 1728

Summary period: 01-10-2017 to 31-10-2017

Date obtained: 13-11-2017

Date published: 22-11-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	40	3	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	30	2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	30
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	3
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	5.7
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	24.2
nonylphenol ethoxylate	ug/L	monthly	1	-	-	9
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	9
zinc	ug/L	monthly	1	-	-	23

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	6	1123	4,800
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

# Cronulla Wastewater Treatment Plant

## September Pollution Monitoring Summary



### EPL 1728

Summary period: 01-09-2017 to 30-09-2017

Date obtained: 06-10-2017

Date published: 17-10-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	40	<2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	30	2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	36
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	3
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	4.2
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	9.2
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	2
zinc	ug/L	monthly	1	-	-	31

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	5	194	530
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

# Cronulla Wastewater Treatment Plant

## August Pollution Monitoring Summary



### EPL 1728

Summary period: 01-08-2017 to 31-08-2017

Date obtained: 18-09-2017

Date published: 21-09-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	40	3	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	30	2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	29
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	5
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	9.8
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	17.2
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	28

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	5	67	180
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

# Cronulla Wastewater Treatment Plant

## July Pollution Monitoring Summary



### EPL 1728

Summary period: 01-07-2017 to 31-07-2017

Date obtained: 17-08-2017

Date published: 23-08-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	40	2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	30	3	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	27
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	3
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	4.6
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	16.1
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	2	3
zinc	ug/L	monthly	1	-	-	22

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	3	7	17
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2.