

Cronulla Wastewater Treatment Plant

June Pollution Monitoring Summary



EPL 1728

Summary period: 01-06-2017 to 30-06-2017

Date obtained: 20-07-2017

Date published: 25-07-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	40	3	yes
oil and grease	mg/L	monthly	15	5	yes
total suspended solids	mg/L	monthly	30	4	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	30
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	4
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	4.7
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	15.7
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	6
zinc	ug/L	monthly	1	-	-	26

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	3	199	920
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2 .

Cronulla Wastewater Treatment Plant

May Pollution Monitoring Summary



EPL 1728

Summary period: 01-05-2017 to 31-05-2017

Date obtained: 20-06-2017

Date published: 23-06-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	40	<2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	30	2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	30
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	5.8
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	7.3
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	3
zinc	ug/L	monthly	1	-	-	27

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	6	<1	55	320
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Cronulla Wastewater Treatment Plant

April Pollution Monitoring Summary



EPL 1728

Summary period: 01-04-2017 to 30-04-2017

Date obtained: 16-05-2017

Date published: 24-05-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	40	<2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	30	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	19
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	3.7
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	11.6
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	18

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	3	50	220
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Cronulla Wastewater Treatment Plant

March Pollution Monitoring Summary



EPL 1728

Summary period: 01-03-2017 to 31-03-2017

Date obtained: 11-04-2017

Date published: 19-04-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	40	<2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	30	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	19
carbonaceous biochemical oxygen demand	mg/L	every 6 days	6	<2	3	19
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	6.2
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	7.2
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	6	<5	<5	<5
total suspended solids	mg/L	every 6 days	6	<2	7	43
zinc	ug/L	monthly	1	-	-	22

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	<1	522	2,600
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	50

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Cronulla Wastewater Treatment Plant

February Pollution Monitoring Summary



EPL 1728

Summary period: 01-02-2017 to 28-02-2017

Date obtained: 07-03-2017

Date published: 14-03-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	40	<2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	30	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	23
carbonaceous biochemical oxygen demand	mg/L	every 6 days	4	<2	<2	<2
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	4.8
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	32.3
nonylphenol ethoxylate	ug/L	monthly	1	-	-	6
oil and grease	mg/L	every 6 days	4	<5	<5	<5
total suspended solids	mg/L	every 6 days	4	<2	<2	<2
zinc	ug/L	monthly	1	-	-	22

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	4	12	19	27
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Cronulla Wastewater Treatment Plant

January Pollution Monitoring Summary



EPL 1728

Summary period: 01-01-2017 to 31-01-2017

Date obtained: 09-02-2017

Date published: 15-02-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	40	3	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	30	3	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	83
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	5
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	8.4
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	11.4
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	2	7
zinc	ug/L	monthly	1	-	-	27

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	6	<1	184	970
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Cronulla Wastewater Treatment Plant

December Pollution Monitoring Summary



EPL 1728

Summary period: 01-12-2016 to 31-12-2016

Date obtained: 10-01-2017

Date published: 13-01-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	40	<2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	30	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	17
carbonaceous biochemical oxygen demand	mg/L	every 6 days	6	<2	<2	<2
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	2.9
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	15.7
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	6	<5	<5	<5
total suspended solids	mg/L	every 6 days	6	<2	<2	<2
zinc	ug/L	monthly	1	-	-	20

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	<1	16	51
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Cronulla Wastewater Treatment Plant

November Pollution Monitoring Summary



EPL 1728

Summary period: 01-11-2016 to 30-11-2016

Date obtained: 05-12-2016

Date published: 12-12-2016

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	40	<2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	30	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	23
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	4.3
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	24
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	3
zinc	ug/L	monthly	1	-	-	26

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	4	115	280
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Cronulla Wastewater Treatment Plant

October Pollution Monitoring Summary



EPL 1728

Summary period: 01-10-2016 to 31-10-2016

Date obtained: 09-11-2016

Date published: 11-11-2016

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	40	<2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	30	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	16
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	7.1
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	22.3
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	33

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	<1	264	1,300
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Cronulla Wastewater Treatment Plant

September Pollution Monitoring Summary



EPL 1728

Summary period: 01-09-2016 to 30-09-2016

Date obtained: 04-10-2016

Date published: 09-10-2016

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	40	<2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	30	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	22
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	2	10
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	5.1
cyanide	ug/L	monthly	1	-	-	9
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	26.7
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	3	14
zinc	ug/L	monthly	1	-	-	22

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	<1	46	210
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Cronulla Wastewater Treatment Plant

August Pollution Monitoring Summary



EPL 1728

Summary period: 01-08-2016 to 31-08-2016

Date obtained: 06-09-2016

Date published: 12-09-2016

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	40	<2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	30	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	16
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	9
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	3.6
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	22
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	3	14
zinc	ug/L	monthly	1	-	-	25

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	<1	77	380
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Cronulla Wastewater Treatment Plant

July Pollution Monitoring Summary



EPL 1728

Summary period: 01-07-2016 to 31-07-2016

Date obtained: 05-08-2016

Date published: 19-08-2016

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	40	3	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	30	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	23
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	7
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	4.9
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	10.5
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	23

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	<1	3	6
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2