

Liverpool Wastewater Treatment Plant

June Pollution Monitoring Summary



EPL 372

Summary period: 01-06-2018 to 30-06-2018

Date obtained: 20-06-2018

Date published: 03-07-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	on bypass	100	33	yes
total suspended solids	mg/L	on bypass	100	130	no ²

² Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

Table 2: Routine monitoring data

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	on bypass	2	23	28	33
faecal coliforms	CFU/100mL	on bypass	2	2,700	171350	340,000
total suspended solids	mg/L	on bypass	2	25	78	130

Table 1: 100 percentile data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	100	2	yes
total suspended solids	mg/L	monthly during discharge	100	4	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	2
total suspended solids	mg/L	monthly during discharge	1	-	-	4

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Liverpool Wastewater Treatment Plant

May Pollution Monitoring Summary

EPL 372



Summary period: 01-05-2018 to 31-05-2018

Date obtained: 22-05-2018

Date published: 01-06-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	100	<2	yes
total suspended solids	mg/L	monthly during discharge	100	4	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	<2
total suspended solids	mg/L	monthly during discharge	1	-	-	4

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Liverpool Wastewater Treatment Plant

April Pollution Monitoring Summary

EPL 372



Summary period: 01-04-2018 to 30-04-2018
 Date obtained: 23-04-2018
 Date published: 03-05-2018

Licensee: Sydney Water Corporation
 PO Box 399
 PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	100	<2	yes
total suspended solids	mg/L	monthly during discharge	100	5	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	<2
total suspended solids	mg/L	monthly during discharge	1	-	-	5

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Liverpool Wastewater Treatment Plant

March Pollution Monitoring Summary

EPL 372



Summary period: 01-03-2018 to 31-03-2018

Date obtained: 23-03-2018

Date published: 04-04-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	100	<2	yes
total suspended solids	mg/L	monthly during discharge	100	5	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	<2
total suspended solids	mg/L	monthly during discharge	1	-	-	5

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Liverpool Wastewater Treatment Plant February Pollution Monitoring Summary



EPL 372

Summary period: 01-02-2018 to 28-02-2018

Date obtained: 06-03-2018

Date published: 15-03-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	on bypass	100	25	yes
total suspended solids	mg/L	on bypass	100	70	yes

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

Table 2: Routine monitoring data

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	on bypass	2	15	20	25
faecal coliforms	CFU/100mL	on bypass	2	6,200	1303100	2,600,000
total suspended solids	mg/L	on bypass	2	31	51	70

Table 1: 100 percentile data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	100	<2	yes
total suspended solids	mg/L	monthly during discharge	100	5	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	<2
total suspended solids	mg/L	monthly during discharge	1	-	-	5

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Liverpool Wastewater Treatment Plant

January Pollution Monitoring Summary

EPL 372



Summary period: 01-01-2018 to 31-01-2018

Date obtained: 22-01-2018

Date published: 02-02-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	100	<2	yes
total suspended solids	mg/L	monthly during discharge	100	6	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	<2
total suspended solids	mg/L	monthly during discharge	1	-	-	6

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Liverpool Wastewater Treatment Plant

December Pollution Monitoring Summary

EPL 372



Summary period: 01-12-2017 to 31-12-2017

Date obtained: 21-12-2017

Date published: 03-01-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	100	9	yes
total suspended solids	mg/L	monthly during discharge	100	2	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	9
total suspended solids	mg/L	monthly during discharge	1	-	-	2

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Liverpool Wastewater Treatment Plant

November Pollution Monitoring Summary

EPL 372



Summary period: 01-11-2017 to 30-11-2017

Date obtained: 24-11-2017

Date published: 01-12-2017

Licensee: Sydney Water Corporation
 PO Box 399
 PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	100	<2	yes
total suspended solids	mg/L	monthly during discharge	100	4	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	<2
total suspended solids	mg/L	monthly during discharge	1	-	-	4

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Liverpool Wastewater Treatment Plant

October Pollution Monitoring Summary

EPL 372



Summary period: 01-10-2017 to 31-10-2017

Date obtained: 25-10-2017

Date published: 01-11-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	100	38	yes
total suspended solids	mg/L	monthly during discharge	100	8	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	38
total suspended solids	mg/L	monthly during discharge	1	-	-	8

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Liverpool Wastewater Treatment Plant

September Pollution Monitoring Summary

EPL 372



Summary period: 01-09-2017 to 30-09-2017

Date obtained: 25-09-2017

Date published: 05-10-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	100	<2	yes
total suspended solids	mg/L	monthly during discharge	100	6	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	<2
total suspended solids	mg/L	monthly during discharge	1	-	-	6

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Liverpool Wastewater Treatment Plant

August Pollution Monitoring Summary

EPL 372



Summary period: 01-08-2017 to 31-08-2017
 Date obtained: 28-08-2017
 Date published: 01-09-2017

Licensee: Sydney Water Corporation
 PO Box 399
 PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	100	5	yes
total suspended solids	mg/L	monthly during discharge	100	9	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	5
total suspended solids	mg/L	monthly during discharge	1	-	-	9

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Liverpool Wastewater Treatment Plant

July Pollution Monitoring Summary

EPL 372



Summary period: 01-07-2017 to 31-07-2017

Date obtained: 28-07-2017

Date published: 09-08-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	100	<2	yes
total suspended solids	mg/L	monthly during discharge	100	11	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	<2
total suspended solids	mg/L	monthly during discharge	1	-	-	11

Average and percentile limits are only applied annually for routine monitoring data in Table 2.