

Rouse Hill Wastewater Treatment Plant

June Pollution Monitoring Summary



EPL 4965

Summary period: 01-06-2018 to 30-06-2018

Date obtained: 04-07-2018

Date published: 11-07-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 4 Site code RH0004		Point description: Outlet of the dechlorination tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	20	<2	yes
total suspended solids	mg/L	monthly	20	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 4 Site code RH0004		Point description: Outlet of the dechlorination tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	204
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
chlorine (total residual)	mg/L	every 6 days	5	<0.04	<0.04	0.04
cobalt	ug/L	monthly	1	-	-	0.2
copper	ug/L	monthly	1	-	-	3.7
cyanide	ug/L	monthly	1	-	-	<5
faecal coliforms	CFU/100mL	every 6 days	5	<1	2	8
iron	ug/L	monthly	1	-	-	18
nitrogen (ammonia)	mg/L	every 6 days	5	0.01	0.02	0.02
nitrogen (total)	mg/L	every 6 days	5	5.66	6.75	8.29
phosphorus (total)	mg/L	every 6 days	5	0.02	0.02	0.02
total suspended solids	mg/L	every 6 days	5	<2	<2	2
zinc	ug/L	monthly	1	-	-	22

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Rouse Hill Wastewater Treatment Plant

May Pollution Monitoring Summary



EPL 4965

Summary period: 01-05-2018 to 31-05-2018

Date obtained: 04-06-2018

Date published: 13-06-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 4 Site code RH0004		Point description: Outlet of the dechlorination tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	20	<2	yes
total suspended solids	mg/L	monthly	20	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 4 Site code RH0004		Point description: Outlet of the dechlorination tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	185
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
chlorine (total residual)	mg/L	every 6 days	5	<0.04	<0.04	<0.04
cobalt	ug/L	monthly	1	-	-	0.3
copper	ug/L	monthly	1	-	-	4.7
cyanide	ug/L	monthly	1	-	-	<5
faecal coliforms	CFU/100mL	every 6 days	5	<1	2	3
iron	ug/L	monthly	1	-	-	24
nitrogen (ammonia)	mg/L	every 6 days	5	0.02	0.05	0.11
nitrogen (total)	mg/L	every 6 days	5	6.05	6.7	7.78
phosphorus (total)	mg/L	every 6 days	5	0.02	0.02	0.03
total suspended solids	mg/L	every 6 days	5	<2	<2	2
zinc	ug/L	monthly	1	-	-	19

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Rouse Hill Wastewater Treatment Plant

April Pollution Monitoring Summary



EPL 4965

Summary period: 01-04-2018 to 30-04-2018

Date obtained: 07-05-2018

Date published: 11-05-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 4 Site code RH0004		Point description: Outlet of the dechlorination tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	20	<2	yes
total suspended solids	mg/L	monthly	20	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 4 Site code RH0004		Point description: Outlet of the dechlorination tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	116
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
chlorine (total residual)	mg/L	every 6 days	5	<0.04	<0.04	<0.04
cobalt	ug/L	monthly	1	-	-	0.3
copper	ug/L	monthly	1	-	-	3.2
cyanide	ug/L	monthly	1	-	-	<5
faecal coliforms	CFU/100mL	every 6 days	5	<1	2	10
iron	ug/L	monthly	1	-	-	24
nitrogen (ammonia)	mg/L	every 6 days	5	0.01	0.59	2.85
nitrogen (total)	mg/L	every 6 days	5	6.36	7.68	9.92
phosphorus (total)	mg/L	every 6 days	5	0.01	0.02	0.04
total suspended solids	mg/L	every 6 days	5	<2	<2	2
zinc	ug/L	monthly	1	-	-	17

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Rouse Hill Wastewater Treatment Plant

March Pollution Monitoring Summary



EPL 4965

Summary period: 01-03-2018 to 31-03-2018

Date obtained: 06-04-2018

Date published: 13-04-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 4 Site code RH0004		Point description: Outlet of the dechlorination tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	20	<2	yes
total suspended solids	mg/L	monthly	20	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 4 Site code RH0004		Point description: Outlet of the dechlorination tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	59
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
chlorine (total residual)	mg/L	every 6 days	5	<0.04	<0.04	<0.04
cobalt	ug/L	monthly	1	-	-	0.3
copper	ug/L	monthly	1	-	-	4.5
cyanide	ug/L	monthly	1	-	-	<5
faecal coliforms	CFU/100mL	every 6 days	5	<1	<1	<1
iron	ug/L	monthly	1	-	-	17
nitrogen (ammonia)	mg/L	every 6 days	5	0.01	0.01	0.02
nitrogen (total)	mg/L	every 6 days	5	5.82	6.66	7.36
phosphorus (total)	mg/L	every 6 days	5	0.01	0.02	0.02
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	18

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Rouse Hill Wastewater Treatment Plant

February Pollution Monitoring Summary



EPL 4965

Summary period: 01-02-2018 to 28-02-2018

Date obtained: 09-03-2018

Date published: 15-03-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 4 Site code RH0004		Point description: Outlet of the dechlorination tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	20	<2	yes
total suspended solids	mg/L	monthly	20	2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 4 Site code RH0004		Point description: Outlet of the dechlorination tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	68
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
chlorine (total residual)	mg/L	every 6 days	5	<0.04	<0.04	0.04
cobalt	ug/L	monthly	1	-	-	0.2
copper	ug/L	monthly	1	-	-	4.3
cyanide	ug/L	monthly	1	-	-	<5
faecal coliforms	CFU/100mL	every 6 days	5	<1	5	22
iron	ug/L	monthly	1	-	-	18
nitrogen (ammonia)	mg/L	every 6 days	5	0.01	0.01	0.02
nitrogen (total)	mg/L	every 6 days	5	5.53	5.93	6.15
phosphorus (total)	mg/L	every 6 days	5	0.01	0.02	0.02
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	19

EPA Point 5 Site code RH0005		Point description: Downstream of the dechlorinated effluent				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
carbonaceous biochemical oxygen demand	mg/L	on bypass	1	-	-	2
faecal coliforms	CFU/100mL	on bypass	1	-	-	59,000
nitrogen (ammonia)	mg/L	on bypass	1	-	-	1.6
nitrogen (total)	mg/L	on bypass	1	-	-	6.26
phosphorus (total)	mg/L	on bypass	1	-	-	0.39
total suspended solids	mg/L	on bypass	1	-	-	9

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Rouse Hill Wastewater Treatment Plant

January Pollution Monitoring Summary



EPL 4965

Summary period: 01-01-2018 to 31-01-2018

Date obtained: 15-02-2018

Date published: 23-02-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 4 Site code RH0004		Point description: Outlet of the dechlorination tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	20	<2	yes
total suspended solids	mg/L	monthly	20	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 4 Site code RH0004		Point description: Outlet of the dechlorination tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	57
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
chlorine (total residual)	mg/L	every 6 days	5	<0.04	<0.04	<0.04
cobalt	ug/L	monthly	1	-	-	0.3
copper	ug/L	monthly	1	-	-	3.7
cyanide	ug/L	monthly	1	-	-	<5
faecal coliforms	CFU/100mL	every 6 days	5	<1	<1	1
iron	ug/L	monthly	1	-	-	17
nitrogen (ammonia)	mg/L	every 6 days	5	0.01	0.02	0.02
nitrogen (total)	mg/L	every 6 days	5	6.89	7.11	7.52
phosphorus (total)	mg/L	every 6 days	5	0.01	0.02	0.02
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	20

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Rouse Hill Wastewater Treatment Plant

December Pollution Monitoring Summary



EPL 4965

Summary period: 01-12-2017 to 31-12-2017

Date obtained: 23-01-2018

Date published: 29-01-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 4 Site code RH0004		Point description: Outlet of the dechlorination tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	20	<2	yes
total suspended solids	mg/L	monthly	20	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 4 Site code RH0004		Point description: Outlet of the dechlorination tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	77
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
chlorine (total residual)	mg/L	every 6 days	5	<0.04	<0.04	<0.04
cobalt	ug/L	monthly	1	-	-	0.3
copper	ug/L	monthly	1	-	-	3.7
cyanide	ug/L	monthly	1	-	-	<5
faecal coliforms	CFU/100mL	every 6 days	5	<1	<1	1
iron	ug/L	monthly	1	-	-	23
nitrogen (ammonia)	mg/L	every 6 days	5	0.01	0.02	0.05
nitrogen (total)	mg/L	every 6 days	5	5.93	6.7	7.5
phosphorus (total)	mg/L	every 6 days	5	0.01	0.02	0.02
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	19

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Rouse Hill Wastewater Treatment Plant

November Pollution Monitoring Summary



EPL 4965

Summary period: 01-11-2017 to 30-11-2017

Date obtained: 11-12-2017

Date published: 14-12-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 4 Site code RH0004		Point description: Outlet of the dechlorination tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	20	<2	yes
total suspended solids	mg/L	monthly	20	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 4 Site code RH0004		Point description: Outlet of the dechlorination tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	78
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
chlorine (total residual)	mg/L	every 6 days	5	<0.04	<0.04	<0.04
cobalt	ug/L	monthly	1	-	-	0.4
copper	ug/L	monthly	1	-	-	3
cyanide	ug/L	monthly	1	-	-	<5
faecal coliforms	CFU/100mL	every 6 days	5	<1	<1	1
iron	ug/L	monthly	1	-	-	17
nitrogen (ammonia)	mg/L	every 6 days	5	0.02	0.06	0.23
nitrogen (total)	mg/L	every 6 days	5	4.86	5.38	6.29
phosphorus (total)	mg/L	every 6 days	5	0.01	0.02	0.02
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	21

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Rouse Hill Wastewater Treatment Plant

October Pollution Monitoring Summary



EPL 4965

Summary period: 01-10-2017 to 31-10-2017

Date obtained: 13-11-2017

Date published: 22-11-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 4 Site code RH0004		Point description: Outlet of the dechlorination tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	20	<2	yes
total suspended solids	mg/L	monthly	20	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 4 Site code RH0004		Point description: Outlet of the dechlorination tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	100
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
chlorine (total residual)	mg/L	every 6 days	5	<0.04	<0.04	<0.04
cobalt	ug/L	monthly	1	-	-	0.4
copper	ug/L	monthly	1	-	-	3
cyanide	ug/L	monthly	1	-	-	<5
faecal coliforms	CFU/100mL	every 6 days	5	<1	<1	1
iron	ug/L	monthly	1	-	-	20
nitrogen (ammonia)	mg/L	every 6 days	5	0.02	0.15	0.32
nitrogen (total)	mg/L	every 6 days	5	4.74	5.05	5.19
phosphorus (total)	mg/L	every 6 days	5	0.01	0.02	0.02
total suspended solids	mg/L	every 6 days	5	<2	<2	3
zinc	ug/L	monthly	1	-	-	23

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Rouse Hill Wastewater Treatment Plant

September Pollution Monitoring Summary



EPL 4965

Summary period: 01-09-2017 to 30-09-2017

Date obtained: 06-10-2017

Date published: 17-10-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 4 Site code RH0004		Point description: Outlet of the dechlorination tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	20	<2	yes
total suspended solids	mg/L	monthly	20	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 4 Site code RH0004		Point description: Outlet of the dechlorination tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	91
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
chlorine (total residual)	mg/L	every 6 days	5	<0.04	<0.04	<0.04
cobalt	ug/L	monthly	1	-	-	0.3
copper	ug/L	monthly	1	-	-	3
cyanide	ug/L	monthly	1	-	-	<5
faecal coliforms	CFU/100mL	every 6 days	5	<1	<1	<1
iron	ug/L	monthly	1	-	-	36
nitrogen (ammonia)	mg/L	every 6 days	5	0.02	0.08	0.19
nitrogen (total)	mg/L	every 6 days	5	4.99	5.41	5.67
phosphorus (total)	mg/L	every 6 days	5	0.01	0.02	0.02
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	22

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Rouse Hill Wastewater Treatment Plant

August Pollution Monitoring Summary



EPL 4965

Summary period: 01-08-2017 to 31-08-2017

Date obtained: 18-09-2017

Date published: 21-09-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 4 Site code RH0004		Point description: Outlet of the dechlorination tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	20	<2	yes
total suspended solids	mg/L	monthly	20	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 4 Site code RH0004		Point description: Outlet of the dechlorination tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	124
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
chlorine (total residual)	mg/L	every 6 days	5	<0.04	<0.04	<0.04
cobalt	ug/L	monthly	1	-	-	0.3
copper	ug/L	monthly	1	-	-	2.1
cyanide	ug/L	monthly	1	-	-	<5
faecal coliforms	CFU/100mL	every 6 days	5	<1	<1	1
iron	ug/L	monthly	1	-	-	18
nitrogen (ammonia)	mg/L	every 6 days	5	0.01	0.06	0.17
nitrogen (total)	mg/L	every 6 days	5	5.35	5.76	6.58
phosphorus (total)	mg/L	every 6 days	5	0.01	0.02	0.02
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	22

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Rouse Hill Wastewater Treatment Plant

July Pollution Monitoring Summary



EPL 4965

Summary period: 01-07-2017 to 31-07-2017

Date obtained: 07-08-2017

Date published: 11-08-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 4 Site code RH0004		Point description: Outlet of the dechlorination tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	20	<2	yes
total suspended solids	mg/L	monthly	20	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 4 Site code RH0004		Point description: Outlet of the dechlorination tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	136
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
chlorine (total residual)	mg/L	every 6 days	6	<0.04	<0.04	<0.04
cobalt	ug/L	monthly	1	-	-	0.3
copper	ug/L	monthly	1	-	-	3.2
cyanide	ug/L	monthly	1	-	-	<5
faecal coliforms	CFU/100mL	every 6 days	6	<1	3	14
iron	ug/L	monthly	1	-	-	47
nitrogen (ammonia)	mg/L	every 6 days	5	0.02	0.04	0.08
nitrogen (total)	mg/L	every 6 days	5	5.55	5.9	6.5
phosphorus (total)	mg/L	every 6 days	5	0.02	0.02	0.02
total suspended solids	mg/L	every 6 days	5	<2	<2	3
zinc	ug/L	monthly	1	-	-	20

Average and percentile limits are only applied annually for routine monitoring data in Table 2