

# Wallacia Wastewater Treatment Plant

## June Pollution Monitoring Summary



### EPL 12235

Summary period: 01-06-2018 to 30-06-2018

Date obtained: 05-07-2018

Date published: 11-07-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 4 Site code WL0004		Point description: From the dechlorination tank			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	25	<2	yes
total suspended solids	mg/L	monthly	25	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 4 Site code WL0004		Point description: From the dechlorination tank				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	5
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
copper	ug/L	monthly	1	-	-	2.7
faecal coliforms	CFU/100mL	every 6 days	5	<1	<1	1
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
nitrogen (ammonia)	mg/L	every 6 days	5	0.01	0.03	0.09
nitrogen (total)	mg/L	every 6 days	5	2.8	3.13	3.82
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
phosphorus (total)	mg/L	every 6 days	5	0.01	0.01	0.02
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	18

Average and percentile limits are only applied annually for routine monitoring data in Table 2

# Wallacia Wastewater Treatment Plant

## May Pollution Monitoring Summary



### EPL 12235

Summary period: 01-05-2018 to 31-05-2018

Date obtained: 04-06-2018

Date published: 13-06-2018

**Licensee:** Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 4 Site code WL0004		Point description: From the dechlorination tank			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	25	<2	yes
total suspended solids	mg/L	monthly	25	2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 4 Site code WL0004		Point description: From the dechlorination tank				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	<5
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
copper	ug/L	monthly	1	-	-	4.1
faecal coliforms	CFU/100mL	every 6 days	5	1	149	740
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
nitrogen (ammonia)	mg/L	every 6 days	5	0.01	0.01	0.03
nitrogen (total)	mg/L	every 6 days	5	2.55	3.07	4.21
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
phosphorus (total)	mg/L	every 6 days	5	0.01	0.01	0.02
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	15

Average and percentile limits are only applied annually for routine monitoring data in Table 2

# Wallacia Wastewater Treatment Plant

## April Pollution Monitoring Summary



### EPL 12235

Summary period: 01-04-2018 to 30-04-2018

Date obtained: 07-05-2018

Date published: 11-05-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 4 Site code WL0004		Point description: From the dechlorination tank			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	25	<2	yes
total suspended solids	mg/L	monthly	25	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 4 Site code WL0004		Point description: From the dechlorination tank				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	<5
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
copper	ug/L	monthly	1	-	-	2.3
faecal coliforms	CFU/100mL	every 6 days	5	1	2	4
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
nitrogen (ammonia)	mg/L	every 6 days	5	<0.01	<0.01	0.01
nitrogen (total)	mg/L	every 6 days	5	2.13	2.78	3.23
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
phosphorus (total)	mg/L	every 6 days	5	0.02	0.02	0.02
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	10

Average and percentile limits are only applied annually for routine monitoring data in Table 2

# Wallacia Wastewater Treatment Plant

## March Pollution Monitoring Summary



### EPL 12235

Summary period: 01-03-2018 to 31-03-2018

Date obtained: 10-04-2018

Date published: 13-04-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 4 Site code WL0004		Point description: From the dechlorination tank			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	25	<2	yes
total suspended solids	mg/L	monthly	25	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 4 Site code WL0004		Point description: From the dechlorination tank				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	<5
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
copper	ug/L	monthly	1	-	-	0.9
faecal coliforms	CFU/100mL	every 6 days	5	1	3	6
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
nitrogen (ammonia)	mg/L	every 6 days	5	0.01	0.01	0.01
nitrogen (total)	mg/L	every 6 days	5	2.96	3.49	4.46
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
phosphorus (total)	mg/L	every 6 days	5	0.02	0.03	0.03
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	10

Average and percentile limits are only applied annually for routine monitoring data in Table 2

# Wallacia Wastewater Treatment Plant

## February Pollution Monitoring Summary



### EPL 12235

Summary period: 01-02-2018 to 28-02-2018

Date obtained: 08-03-2018

Date published: 15-03-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 4 Site code WL0004	Point description: From the dechlorination tank				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	25	<2	yes
total suspended solids	mg/L	monthly	25	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 4 Site code WL0004	Point description: From the dechlorination tank					
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	<5
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
copper	ug/L	monthly	1	-	-	3.6
faecal coliforms	CFU/100mL	every 6 days	5	<1	6	16
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
nitrogen (ammonia)	mg/L	every 6 days	5	0.01	0.01	0.01
nitrogen (total)	mg/L	every 6 days	5	2.48	2.79	3.54
nonylphenol ethoxylate	ug/L	monthly	1	-	-	10
phosphorus (total)	mg/L	every 6 days	5	0.02	0.02	0.02
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	11

Average and percentile limits are only applied annually for routine monitoring data in Table 2

# Wallacia Wastewater Treatment Plant

## January Pollution Monitoring Summary



### EPL 12235

Summary period: 01-01-2018 to 31-01-2018

Date obtained: 19-02-2018

Date published: 23-02-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 4 Site code WL0004		Point description: From the dechlorination tank			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	25	<2	yes
total suspended solids	mg/L	monthly	25	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 4 Site code WL0004		Point description: From the dechlorination tank				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	<5
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
copper	ug/L	monthly	1	-	-	2.4
faecal coliforms	CFU/100mL	every 6 days	5	<1	2	4
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
nitrogen (ammonia)	mg/L	every 6 days	5	<0.01	<0.01	0.01
nitrogen (total)	mg/L	every 6 days	5	2.33	2.79	3.41
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
phosphorus (total)	mg/L	every 6 days	5	0.02	0.02	0.02
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	11

Average and percentile limits are only applied annually for routine monitoring data in Table 2

# Wallacia Wastewater Treatment Plant

## December Pollution Monitoring Summary



### EPL 12235

Summary period: 01-12-2017 to 31-12-2017

Date obtained: 23-01-2018

Date published: 29-01-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 4 Site code WL0004	Point description: From the dechlorination tank				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	25	<2	yes
total suspended solids	mg/L	monthly	25	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 4 Site code WL0004	Point description: From the dechlorination tank					
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	<5
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
copper	ug/L	monthly	1	-	-	2.3
faecal coliforms	CFU/100mL	every 6 days	5	<1	<1	1
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	216
nitrogen (ammonia)	mg/L	every 6 days	5	0.01	0.01	0.01
nitrogen (total)	mg/L	every 6 days	5	1.89	2.57	3.96
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
phosphorus (total)	mg/L	every 6 days	5	0.02	0.02	0.02
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	12

Average and percentile limits are only applied annually for routine monitoring data in Table 2

# Wallacia Wastewater Treatment Plant

## November Pollution Monitoring Summary



### EPL 12235

Summary period: 01-11-2017 to 30-11-2017

Date obtained: 13-12-2017

Date published: 21-12-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 4 Site code WL0004		Point description: From the dechlorination tank			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	25	<2	yes
total suspended solids	mg/L	monthly	25	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 4 Site code WL0004		Point description: From the dechlorination tank				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	<5
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
copper	ug/L	monthly	1	-	-	2.2
faecal coliforms	CFU/100mL	every 6 days	5	<1	2	5
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	38
nitrogen (ammonia)	mg/L	every 6 days	5	0.01	0.02	0.04
nitrogen (total)	mg/L	every 6 days	5	2.22	3.29	4.93
nonylphenol ethoxylate	ug/L	monthly	1	-	-	8
phosphorus (total)	mg/L	every 6 days	5	0.02	0.02	0.03
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	12

Average and percentile limits are only applied annually for routine monitoring data in Table 2



# Wallacia Wastewater Treatment Plant

## October Pollution Monitoring Summary



### EPL 12235

Summary period: 01-10-2017 to 31-10-2017

Date obtained: 13-11-2017

Date published: 22-11-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 4 Site code WL0004		Point description: From the dechlorination tank			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	25	<2	yes
total suspended solids	mg/L	monthly	25	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 4 Site code WL0004		Point description: From the dechlorination tank				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	<5
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
copper	ug/L	monthly	1	-	-	2.1
faecal coliforms	CFU/100mL	every 6 days	6	<1	<1	1
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
nitrogen (ammonia)	mg/L	every 6 days	5	<0.01	0.01	0.03
nitrogen (total)	mg/L	every 6 days	5	2.27	2.74	3.49
nonylphenol ethoxylate	ug/L	monthly	1	-	-	11
phosphorus (total)	mg/L	every 6 days	5	0.02	0.03	0.03
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	13

Average and percentile limits are only applied annually for routine monitoring data in Table 2

# Wallacia Wastewater Treatment Plant

## September Pollution Monitoring Summary



### EPL 12235

Summary period: 01-09-2017 to 30-09-2017

Date obtained: 09-10-2017

Date published: 19-10-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 4 Site code WL0004		Point description: From the dechlorination tank			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	25	<2	yes
total suspended solids	mg/L	monthly	25	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 4 Site code WL0004		Point description: From the dechlorination tank				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	<5
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
copper	ug/L	monthly	1	-	-	2.2
faecal coliforms	CFU/100mL	every 6 days	5	<1	2	7
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
nitrogen (ammonia)	mg/L	every 6 days	5	0.01	0.02	0.02
nitrogen (total)	mg/L	every 6 days	5	2.16	2.49	2.73
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
phosphorus (total)	mg/L	every 6 days	5	0.01	0.02	0.03
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	15

Average and percentile limits are only applied annually for routine monitoring data in Table 2

# Wallacia Wastewater Treatment Plant

## August Pollution Monitoring Summary



### EPL 12235

Summary period: 01-08-2017 to 31-08-2017

Date obtained: 18-09-2017

Date published: 21-09-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 4 Site code WL0004		Point description: From the dechlorination tank			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	25	<2	yes
total suspended solids	mg/L	monthly	25	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 4 Site code WL0004		Point description: From the dechlorination tank				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	<5
carbonaceous biochemical oxygen demand	mg/L	every 6 days	6	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
copper	ug/L	monthly	1	-	-	2.1
faecal coliforms	CFU/100mL	every 6 days	5	<1	59	290
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
nitrogen (ammonia)	mg/L	every 6 days	6	0.01	0.06	0.24
nitrogen (total)	mg/L	every 6 days	6	2.58	3.16	4.5
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
phosphorus (total)	mg/L	every 6 days	6	0.02	0.04	0.11
total suspended solids	mg/L	every 6 days	6	<2	<2	<2
zinc	ug/L	monthly	1	-	-	18

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

# Wallacia Wastewater Treatment Plant

## July Pollution Monitoring Summary



### EPL 12235

Summary period: 01-07-2017 to 31-07-2017

Date obtained: 17-08-2017

Date published: 23-08-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 4 Site code WL0004		Point description: From the dechlorination tank			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	25	<2	yes
total suspended solids	mg/L	monthly	25	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 4 Site code WL0004		Point description: From the dechlorination tank				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	<5
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
copper	ug/L	monthly	1	-	-	3
faecal coliforms	CFU/100mL	every 6 days	5	<1	280	1,400
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
nitrogen (ammonia)	mg/L	every 6 days	5	0.01	0.02	0.03
nitrogen (total)	mg/L	every 6 days	5	2.5	3.16	4.11
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
phosphorus (total)	mg/L	every 6 days	5	0.02	0.04	0.08
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	15

Average and percentile limits are only applied annually for routine monitoring data in Table 2.