

Warriewood Wastewater Treatment Plant

June Pollution Monitoring Summary



EPL 1784

Summary period: 01-06-2018 to 30-06-2018

Date obtained: 04-07-2018

Date published: 11-07-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	80	4	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	16
copper	ug/L	monthly	1	-	-	4.6
cyanide	ug/L	monthly	1	-	-	<5
faecal coliforms	CFU/100mL	every 6 days	5	25	109	350
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	27.8
total suspended solids	mg/L	every 6 days	5	4	9	16

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Warriewood Wastewater Treatment Plant

May Pollution Monitoring Summary



EPL 1784

Summary period: 01-05-2018 to 31-05-2018

Date obtained: 06-06-2018

Date published: 13-06-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	80	7	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	18
copper	ug/L	monthly	1	-	-	5.9
cyanide	ug/L	monthly	1	-	-	<5
faecal coliforms	CFU/100mL	every 6 days	5	630	11292	41,000
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	43.4
total suspended solids	mg/L	every 6 days	6	6	11	21

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Warriewood Wastewater Treatment Plant

April Pollution Monitoring Summary



EPL 1784

Summary period: 01-04-2018 to 30-04-2018

Date obtained: 03-05-2018

Date published: 11-05-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	80	3	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	9
copper	ug/L	monthly	1	-	-	1.7
cyanide	ug/L	monthly	1	-	-	<5
faecal coliforms	CFU/100mL	every 6 days	5	63	6767	32,000
nonylphenol ethoxylate	ug/L	monthly	1	-	-	6
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	42.9
total suspended solids	mg/L	every 6 days	5	<2	4	8

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Warriewood Wastewater Treatment Plant

March Pollution Monitoring Summary



EPL 1784

Summary period: 01-03-2018 to 31-03-2018

Date obtained: 04-04-2018

Date published: 13-04-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	80	3	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	9
copper	ug/L	monthly	1	-	-	2.3
cyanide	ug/L	monthly	1	-	-	15
faecal coliforms	CFU/100mL	every 6 days	5	50	870	3,800
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	54.3
total suspended solids	mg/L	every 6 days	5	3	5	6

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Warriewood Wastewater Treatment Plant

February Pollution Monitoring Summary



EPL 1784

Summary period: 01-02-2018 to 28-02-2018

Date obtained: 06-03-2018

Date published: 15-03-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	80	4	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	10
copper	ug/L	monthly	1	-	-	2.5
cyanide	ug/L	monthly	1	-	-	8
faecal coliforms	CFU/100mL	every 6 days	5	39	681	3,000
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	50.57
total suspended solids	mg/L	every 6 days	4	2	4	5

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Warriewood Wastewater Treatment Plant

January Pollution Monitoring Summary



EPL 1784

Summary period: 01-01-2018 to 31-01-2018

Date obtained: 19-02-2018

Date published: 23-02-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	80	5	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	11
copper	ug/L	monthly	1	-	-	2.1
cyanide	ug/L	monthly	1	-	-	<5
faecal coliforms	CFU/100mL	every 6 days	5	210	2120	7,900
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	75.7
total suspended solids	mg/L	every 6 days	6	3	5	6

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Warriewood Wastewater Treatment Plant

December Pollution Monitoring Summary



EPL 1784

Summary period: 01-12-2017 to 31-12-2017

Date obtained: 23-01-2018

Date published: 29-01-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	80	4	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	11
copper	ug/L	monthly	1	-	-	2.1
cyanide	ug/L	monthly	1	-	-	<5
faecal coliforms	CFU/100mL	every 6 days	5	61	5492	9,600
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	49.3
total suspended solids	mg/L	every 6 days	5	4	6	8

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Warriewood Wastewater Treatment Plant

November Pollution Monitoring Summary



EPL 1784

Summary period: 01-11-2017 to 30-11-2017

Date obtained: 14-12-2017

Date published: 21-12-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	80	4	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	16
copper	ug/L	monthly	1	-	-	3
cyanide	ug/L	monthly	1	-	-	<5
faecal coliforms	CFU/100mL	every 6 days	5	150	3992	10,000
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	79.3
total suspended solids	mg/L	every 6 days	5	3	3	4

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Warriewood Wastewater Treatment Plant

October Pollution Monitoring Summary



EPL 1784

Summary period: 01-10-2017 to 31-10-2017

Date obtained: 13-11-2017

Date published: 22-11-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	80	5	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	9
copper	ug/L	monthly	1	-	-	1.8
cyanide	ug/L	monthly	1	-	-	<5
faecal coliforms	CFU/100mL	every 6 days	5	25	1247	3,200
nonylphenol ethoxylate	ug/L	monthly	1	-	-	14
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	62.3
total suspended solids	mg/L	every 6 days	5	4	4	5

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Warriewood Wastewater Treatment Plant

September Pollution Monitoring Summary



EPL 1784

Summary period: 01-09-2017 to 30-09-2017

Date obtained: 06-10-2017

Date published: 17-10-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	80	3	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	11
copper	ug/L	monthly	1	-	-	3
cyanide	ug/L	monthly	1	-	-	<5
faecal coliforms	CFU/100mL	every 6 days	5	14	1324	6,500
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	56.8
total suspended solids	mg/L	every 6 days	5	<2	2	3

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Warriewood Wastewater Treatment Plant

August Pollution Monitoring Summary



EPL 1784

Summary period: 01-08-2017 to 31-08-2017

Date obtained: 18-09-2017

Date published: 21-09-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	80	3	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	8
copper	ug/L	monthly	1	-	-	2.8
cyanide	ug/L	monthly	1	-	-	<5
faecal coliforms	CFU/100mL	every 6 days	5	30	649	3,000
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	76.5
total suspended solids	mg/L	every 6 days	5	3	4	6

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Warriewood Wastewater Treatment Plant

July Pollution Monitoring Summary



EPL 1784

Summary period: 01-07-2017 to 31-07-2017

Date obtained: 17-08-2017

Date published: 23-08-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	80	5	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	12
copper	ug/L	monthly	1	-	-	2.9
cyanide	ug/L	monthly	1	-	-	<5
faecal coliforms	CFU/100mL	every 6 days	5	12	154	540
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	43.1
total suspended solids	mg/L	every 6 days	5	3	5	7

Average and percentile limits are only applied annually for routine monitoring data in Table 2.