

Riverstone Wastewater Treatment Plant 2019-20 Pollution Monitoring Summary



EPL 1796

Summary period: 01-07-2019 to 30-06-2020

Date published: 10-08-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 50 percentile yearly summary								
EPA Point 3 Site code RS0003		Point description: Downstream of the weir in the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
carbonaceous biochemical oxygen demand	mg/L	every 6 days	61	<2	<2	10	<2	yes
nitrogen (ammonia)	mg/L	every 6 days	61	<0.01	5.27	1	0.01	yes
total suspended solids	mg/L	every 6 days	61	<2	7	10	<2	yes

Table 1: 50 percentile yearly summary								
EPA Point 4 Site code RS0004		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	12	100	100	50	100	yes

Riverstone Wastewater Treatment Plant 2019-20 Pollution Monitoring Summary

EPL 1796

Summary period: 01-07-2019 to 30-06-2020

Date published: 10-08-2020



Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 2: 80 percentile yearly summary

EPA Point 4 Site code RS0004		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	80 percentile limit	80 percentile value	within limits
faecal coliforms	CFU/100mL	every 6 days	61	<1	57	200	14	yes

Riverstone Wastewater Treatment Plant 2019-20 Pollution Monitoring Summary

EPL 1796

Summary period: 01-07-2019 to 30-06-2020

Date published: 10-08-2020



Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 3: 90 percentile yearly summary

EPA Point 3 Site code RS0003		Point description: Downstream of the weir in the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limit
aluminium	ug/L	monthly	12	26	118	3,200	49	yes
carbonaceous biochemical oxygen demand	mg/L	every 6 days	61	<2	<2	15	<2	yes
cobalt	ug/L	monthly	12	0.2	0.5	8	0.4	yes
copper	ug/L	monthly	12	<0.5	7.9	79	4.9	yes
cyanide	ug/L	monthly	12	<5	<5	240	<5	yes
iron	ug/L	monthly	12	7	24	650	21	yes
nickel	ug/L	monthly	12	0.8	2	120	1.7	yes
nitrogen (ammonia)	mg/L	every 6 days	61	<0.01	5.27	5	0.02	yes
total suspended solids	mg/L	every 6 days	61	<2	7	15	<2	yes
zinc	ug/L	monthly	12	6	160	990	12	yes

Table 3: 90 percentile yearly summary

EPA Point 4 Site code RS0004		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limit
chlorine (total residual)	mg/L	every 6 days	61	<0.04	0.51	0.1	<0.04	yes
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	340	<30	yes

Riverstone Wastewater Treatment Plant 2019-20 Pollution Monitoring Summary

EPL 1796

Summary period: 01-07-2019 to 30-06-2020

Date published: 10-08-2020



Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 4: 100 percentile yearly summary

EPA Point 3 Site code RS0003		Point description: Downstream of the weir in the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	100 percentile limit	100 percentile value	within limits
nitrogen (total)	mg/L	every 6 days	61	0.72	8.25	45	8.25	yes
phosphorus	mg/L	every 6 days	61	0.01	0.05	5	0.05	yes

Riverstone Wastewater Treatment Plant 2019-20 Pollution Monitoring Summary

EPL 1796

Summary period: 01-07-2019 to 30-06-2020

Date published: 10-08-2020



Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 5: Average yearly summary

EPA Point 3 Site code RS0003		Point description: Downstream of the weir in the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average limit	Average value	within limits
aluminium	ug/L	monthly	12	26	118	330	43	yes
cobalt	ug/L	monthly	12	0.2	0.5	2.9	0.4	yes
copper	ug/L	monthly	12	<0.5	7.9	14.4	2	yes
cyanide	ug/L	monthly	12	<5	<5	21	<5	yes
iron	ug/L	monthly	12	7	24	380	14	yes
nickel	ug/L	monthly	12	0.8	2	35	1	yes
zinc	ug/L	monthly	12	6	160	70	21	yes

Table 5: Average yearly summary

EPA Point 4 Site code RS0004		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average limit	Average value	within limits
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	83	<30	yes