

# Wollongong Wastewater Treatment Plant

## January Pollution Monitoring Summary



### EPL 218

Summary period: 01-01-2021 to 31-01-2021

Date obtained: 09-02-2021

Date published: 12-02-2021

**Licensee:** Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 5 Site code WO0005		Point description: At the inlet to the effluent pumping station				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	50	8	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 5 Site code WO0005		Point description: At the inlet to the effluent pumping station				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	238
biochemical oxygen demand	mg/L	every 6 days	5	4	7.6	19
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	2	12
copper	ug/L	monthly	1	-	-	11.6
diazinon	ug/L	monthly	1	-	-	<0.1
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
total suspended solids	mg/L	every 6 days	5	<2	5	24

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Wollongong Wastewater Treatment Plant

## December Pollution Monitoring Summary



### EPL 218

Summary period: 01-12-2020 to 31-12-2020

Date obtained: 08-01-2021

Date published: 18-01-2021

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 5 Site code WO0005		Point description: At the inlet to the effluent pumping station				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	50	2	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 5 Site code WO0005		Point description: At the inlet to the effluent pumping station				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	13
biochemical oxygen demand	mg/L	every 6 days	5	3	8.8	18
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	3	8
copper	ug/L	monthly	1	-	-	4.2
diazinon	ug/L	monthly	1	-	-	<0.1
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
total suspended solids	mg/L	every 6 days	5	<2	7	17

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Wollongong Wastewater Treatment Plant

## November Pollution Monitoring Summary



### EPL 218

Summary period: 01-11-2020 to 30-11-2020

Date obtained: 08-12-2020

Date published: 15-12-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 5 Site code WO0005		Point description: At the inlet to the effluent pumping station				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	50	6	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 5 Site code WO0005		Point description: At the inlet to the effluent pumping station				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	205
biochemical oxygen demand	mg/L	every 6 days	5	4	8.6	18
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	3	15
copper	ug/L	monthly	1	-	-	10.4
diazinon	ug/L	monthly	1	-	-	<0.1
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
total suspended solids	mg/L	every 6 days	5	<2	9	32

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Wollongong Wastewater Treatment Plant

## October Pollution Monitoring Summary



### EPL 218

Summary period: 01-10-2020 to 31-10-2020

Date obtained: 10-11-2020

Date published: 13-11-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 5 Site code WO0005		Point description: At the inlet to the effluent pumping station				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	50	2	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 5 Site code WO0005		Point description: At the inlet to the effluent pumping station				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	16
biochemical oxygen demand	mg/L	every 6 days	5	3	4.4	6
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	3
copper	ug/L	monthly	1	-	-	4.1
diazinon	ug/L	monthly	1	-	-	<0.1
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
total suspended solids	mg/L	every 6 days	5	<2	<2	5

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Wollongong Wastewater Treatment Plant

## September Pollution Monitoring Summary



### EPL 218

Summary period: 01-09-2020 to 30-09-2020

Date obtained: 12-10-2020

Date published: 19-10-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 5 Site code WO0005		Point description: At the inlet to the effluent pumping station				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	50	2	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 5 Site code WO0005		Point description: At the inlet to the effluent pumping station				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	22
biochemical oxygen demand	mg/L	every 6 days	5	3	3.6	4
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
copper	ug/L	monthly	1	-	-	4.2
diazinon	ug/L	monthly	1	-	-	<0.1
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
total suspended solids	mg/L	every 6 days	5	<2	<2	2

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

Note: biochemical oxygen demand monitoring commenced from September 2020.

# Wollongong Wastewater Treatment Plant

## August Pollution Monitoring Summary



### EPL 218

Summary period: 01-08-2020 to 31-08-2020

Date obtained: 07-09-2020

Date published: 16-09-2020

**Licensee:** Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 5 Site code WO0005		Point description: At the inlet to the effluent pumping station				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	50	24	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 5 Site code WO0005		Point description: At the inlet to the effluent pumping station				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	181
carbonaceous biochemical oxygen demand	mg/L	every 6 days	6	<2	3	11
copper	ug/L	monthly	1	-	-	6.7
diazinon	ug/L	monthly	1	-	-	<0.1
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
total suspended solids	mg/L	every 6 days	6	3	7	17

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Wollongong Wastewater Treatment Plant

## July Pollution Monitoring Summary



### EPL 218

Summary period: 01-07-2020 to 31-07-2020

Date obtained: 04-08-2020

Date published: 14-08-2020

**Licensee:** Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 5 Site code WO0005		Point description: At the inlet to the effluent pumping station				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	50	<2	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 5 Site code WO0005		Point description: At the inlet to the effluent pumping station				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	16
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	5	19
copper	ug/L	monthly	1	-	-	2.8
diazinon	ug/L	monthly	1	-	-	<0.1
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
total suspended solids	mg/L	every 6 days	5	<2	5	23

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).