

Penrith Wastewater Treatment Plant

2016-17 Pollution monitoring yearly limit summaries



EPL 1409

Summary period: 01-07-2016 to 30-06-2017

Date published: 11-08-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

50 percentile yearly summary								
EPA Point 5 Site code PR0005		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
carbonaceous biochemical oxygen demand	mg/L	every 6 days	60	<2	8	10	<2	yes
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	11	<6.25	100	50	100	yes
nitrogen (ammonia)	mg/L	every 6 days	60	<0.01	2.25	1	0.02	yes
nitrogen (total)	mg/L	every 6 days	60	2.13	6.58	10	4.27	yes
phosphorus (total)	mg/L	every 6 days	60	0.05	0.22	0.2	0.07	yes
total suspended solids	mg/L	every 6 days	60	<2	4	10	<2	yes

80 percentile yearly summary								
EPA Point 5 Site code PR0005		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	80 percentile limit	80 percentile value	within limits
faecal coliforms	CFU/100mL	every 6 days	61	<1	280	200	36	yes

Penrith Wastewater Treatment Plant

2016-17 Pollution monitoring yearly limit summaries



EPL 1409

Summary period: 01-07-2016 to 30-06-2017

Date published: 11-08-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

90 percentile yearly summary								
EPA Point 5 Site code PR0005	Point description: At the outlet of the chlorine contact tank							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
aluminium	ug/L	monthly	12	46	218	2,000	204	yes
arsenic	ug/L	monthly	12	0.2	0.7	1,400	0.4	yes
cadmium	ug/L	monthly	12	<0.1	<0.1	350	<0.1	yes
carbonaceous biochemical oxygen demand	mg/L	every 6 days	60	<2	8	15	<2	yes
cobalt	ug/L	monthly	12	0.7	1.1	2	1	yes
copper	ug/L	monthly	12	3.6	5.9	96	5	yes
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	530	<30	yes
iron	ug/L	monthly	12	91	152	2,600	146	yes
nickel	ug/L	monthly	12	1.5	2.7	170	2.4	yes
nitrogen (ammonia)	mg/L	every 6 days	60	<0.01	2.25	5	0.04	yes
nitrogen (total)	mg/L	every 6 days	60	2.13	6.58	15	5.2	yes
phosphorus (total)	mg/L	every 6 days	60	0.05	0.22	0.4	0.12	yes
total suspended solids	mg/L	every 6 days	60	<2	4	15	2	yes
zinc	ug/L	monthly	12	29	38	210	38	yes

Penrith Wastewater Treatment Plant

2016-17 Pollution monitoring yearly limit summaries



EPL 1409

Summary period: 01-07-2016 to 30-06-2017
Date published: 11-08-2017

Licensee: Sydney Water Corporation

PO Box 399
PARRAMATTA NSW 2124

Average yearly summary								
EPA Point 5 Site code PR0005		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average Limit	Average value	within limits
aluminium	ug/L	monthly	12	46	218	510	150	yes
arsenic	ug/L	monthly	12	0.2	0.7	44	<0.3	yes
cadmium	ug/L	monthly	12	<0.1	<0.1	8.2	<0.1	yes
cobalt	ug/L	monthly	12	0.7	1.1	1.5	0.9	yes
copper	ug/L	monthly	12	3.6	5.9	14.7	5	yes
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	85	<30	yes
iron	ug/L	monthly	12	91	152	330	118	yes
nickel	ug/L	monthly	12	1.5	2.7	22	2	yes
zinc	ug/L	monthly	12	29	38	60	34	yes

90 percentile yearly summary								
EPA Point 21 Site code PR0021		Point description: Downstream of the St Marys Advanced Water Treatment Plant return stream						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
chlorine (total residual)	mg/L	every 6 days	61	<0.04	0.54	0.1	<0.04	yes

50 percentile yearly summary								
EPA Point 22 Site code PR0022		Point description: Upstream of the St Marys Advanced Water Treatment Plant return stream						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	100	50	100	yes