

# Bombo Wastewater Treatment Plant

## 2017-18 Pollution monitoring yearly limit summaries



### EPL 2269

Summary period: 01-07-2017 to 30-06-2018

Date published: 14-09-2018

**Licensee:** Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

50 percentile yearly summary								
EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
aluminium	ug/L	monthly	12	27	111	150	39	yes
carbonaceous biochemical oxygen demand	mg/L	every 6 days	60	<2	22	15	3	yes
copper	ug/L	monthly	12	2.5	7.9	63	3	yes
diazinon	ug/L	monthly	12	<0.1	<0.1	0.5	<0.1	yes
nitrogen (ammonia)	mg/L	monthly	12	1.3	13.5	47.1	6.8	yes
nonylphenol ethoxylate	ug/L	monthly	12	<5	13	52	<5	yes
total suspended solids	mg/L	every 6 days	60	<2	220	20	4	yes

# Bombo Wastewater Treatment Plant

## 2017-18 Pollution monitoring yearly limit summaries



### EPL 2269

Summary period: 01-07-2017 to 30-06-2018  
Date published: 13-09-2018

**Licensee:** Sydney Water Corporation  
PO Box 399  
PARRAMATTA NSW 2124

90 percentile yearly summary								
EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
aluminium	ug/L	monthly	12	27	111	990	102	yes
copper	ug/L	monthly	12	2.5	7.9	100	6	yes
diazinon	ug/L	monthly	12	<0.1	<0.1	6.2	<0.1	yes
nitrogen (ammonia)	mg/L	monthly	12	1.3	13.5	82.8	13.2	yes
nonylphenol ethoxylate	ug/L	monthly	12	<5	13	90	8	yes
total suspended solids	mg/L	every 6 days	60	<2	220	40	18	yes

50 percentile yearly summary								
EPA Point 13 Site code BO0013		Point description: In the channel after the dechlorination unit						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
faecal coliforms	CFU/100mL	every 6 days	61	<1	42,000	150	2	yes
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	390	240	<30	yes

# Bombo Wastewater Treatment Plant

## 2017-18 Pollution monitoring yearly limit summaries



### EPL 2269

Summary period: 01-07-2017 to 30-06-2018  
Date published: 13-09-2018

**Licensee:** Sydney Water Corporation  
PO Box 399  
PARRAMATTA NSW 2124

90 percentile yearly summary								
EPA Point 13 Site code BO0013		Point description: In the channel after the dechlorination unit						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	390	1,000	88	yes

90 percentile yearly summary								
EPA Point 13 Site code BO0013		Point description: In the channel after the dechlorination unit						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	12	92.8	100	1.18	100	yes

Average yearly summary								
EPA Point 13 Site code BO0013		Point description: In the channel after the dechlorination unit						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average Limit	Average value	within limits
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	12	92.8	100	2.16	99.4	yes