

# North Richmond Wastewater Treatment Plant

## 2017-18 Pollution monitoring yearly limit summaries



### EPL 190

Summary period: 01-07-2017 to 30-06-2018

Date published: 14-09-2018

**Licensee:** Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

50 percentile yearly summary								
EPA Point 4 Site code NR0004		Point description: Downstream of the weir from the disinfection facilities						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
carbonaceous biochemical oxygen demand	mg/L	every 6 days	61	<2	10	10	<2	yes
nitrogen (ammonia)	mg/L	every 6 days	61	0.18	1.93	2	0.5	yes
nitrogen (total)	mg/L	every 6 days	61	5.45	9.24	10	6.5	yes
phosphorus (total)	mg/L	every 6 days	61	0.05	0.39	2	0.12	yes
total suspended solids	mg/L	every 6 days	61	<2	11	20	4	yes

# North Richmond Wastewater Treatment Plant

## 2017-18 Pollution monitoring yearly limit summaries



### EPL 190

Summary period: 01-07-2017 to 30-06-2018

Date published: 13-09-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

90 percentile yearly summary								
EPA Point 4 Site code NR0004	Point description: Downstream of the weir from the disinfection facilities							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
aluminium	ug/L	monthly	12	257	812	1,600	794	yes
carbonaceous biochemical oxygen demand	mg/L	every 6 days	61	<2	10	15	3	yes
copper	ug/L	monthly	12	3.6	6	270	6	yes
cyanide	ug/L	monthly	12	<5	<5	220	<5	yes
diazinon	ug/L	monthly	12	<0.1	<0.1	27	<0.1	yes
iron	ug/L	monthly	12	18	81	510	49	yes
nitrogen (ammonia)	mg/L	every 6 days	61	0.18	1.93	5	0.79	yes
nitrogen (total)	mg/L	every 6 days	61	5.45	9.24	15	8	yes
phosphorus (total)	mg/L	every 6 days	61	0.05	0.39	5	0.26	yes
total suspended solids	mg/L	every 6 days	61	<2	11	30	7	yes
zinc	ug/L	monthly	12	29	52	140	45	yes

# North Richmond Wastewater Treatment Plant

## 2017-18 Pollution monitoring yearly limit summaries



### EPL 190

Summary period: 01-07-2017 to 30-06-2018

Date published: 13-09-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Average yearly summary								
EPA Point 4 Site code NR0004		Point description: Downstream of the weir from the disinfection facilities						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average Limit	Average value	within limits
aluminium	ug/L	monthly	12	257	812	500	455	yes
copper	ug/L	monthly	12	3.6	6	27	4	yes
cyanide	ug/L	monthly	12	<5	<5	19	<5	yes
diazinon	ug/L	monthly	12	<0.1	<0.1	1.3	<0.1	yes
iron	ug/L	monthly	12	18	81	340	33	yes
zinc	ug/L	monthly	12	29	52	49	39	yes

50 percentile yearly summary								
EPA Point 5 Site code NR0005		Point description: Outlet of the disinfection facilities						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	12	100	100	50	100	yes

80 percentile yearly summary								
EPA Point 5 Site code NR0005		Point description: Outlet of the disinfection facilities						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	80 percentile limit	80 percentile value	within limits
faecal coliforms	CFU/100mL	every 6 days	61	<1	280	200	7	yes

# North Richmond Wastewater Treatment Plant

## 2017-18 Pollution monitoring yearly limit summaries



### EPL 190

Summary period: 01-07-2017 to 30-06-2018

Date published: 13-09-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

90 percentile yearly summary								
EPA Point 5 Site code NR0005		Point description: Outlet of the disinfection facilities						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	36	350	33	yes

Average yearly summary								
EPA Point 5 Site code NR0005		Point description: Outlet of the disinfection facilities						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average Limit	Average value	within limits
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	36	79	<30	yes